

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: September/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.03
2				.04			.04
3				.04			.04
4				.05			.09
5				.06			.07
6				.08			.10
7				.09			.11
8				.02			.02
9				.02			.02
10				.02			.02
11				.02			.02
12				.04			.04
13				.04			.04
14				.06			
15	maintenance			shut down			
16				.09			.10
17				.08			.09
18				.08			.08
19				.08			.08
20							
21	PLANT SHUTDOWN FOR REPAIRS						
22							
23							
24							
25				.11			.11
26	maintenance			shut down			
27				.20			.20
28				.21			.21
29				.23			.23
30				.07			.07
31							

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Burch	
	SIGNATURE: <i>Jeff Burch</i>	DATE: 10-10-22
	PHONE #: (503) 816-0958	CERT #: 6091

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: September 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]	
1 19:00	.85	72	61.2	19.2	7.90	18	Yes	12	
2 15:00	.81		58.32	19.5	7.80	18	Yes	12	
3 12:25	.75		54	17.7	7.90	18	Yes	12	
4 12:55	.87		62.64	17.6	7.80	18	Yes	12	
5 16:35	.83		59.76	17.4	7.80	18	Yes	12	
6 14:05	.76		54.72	17.2	7.80	18	Yes	12	
7 16:45	.98		70.56	17.1	7.80	18	Yes	12	
8 19:50	1.08		77.76	16.9	7.90	18	Yes	12	
9 12:05	.79		56.88	17.0	7.90	18	Yes	12	
10 15:45	.96		69.12	16.6	7.90	18	Yes	12	
11 12:05	.81		58.32	16.3	7.90	18	Yes	12	
12 18:30	.73		52.56	17.0	7.90	18	Yes	12	
13 17:00	.75		54	16.7	7.90	18	Yes	12	
14 18:00	.81		58.32	16.5	7.80	18	Yes	12	
15 /	maint: rec		Shut down					12	
16 16:50	.89		64.08	16.4	7.80	18	Yes	12	
17 16:30	.85		61.2	15.8	7.80	18	Yes	12	
18 14:30	.63		45.36	15.6	7.90	18	Yes	12	
19 16:35	.72		51.84	15.6	7.80	18	Yes	12	
20 10:40	.67		48.24	15.9	7.80	18	Yes	12	
21 /									
22 /									
23 /	PLANT SHUTDOWN FOR REPAIRS								
24 /									
25 16:05	.71		51.12	15.0	7.80	18	Yes	12	
26 /	maint: rec		shut down						
27 16:00	.63		45.36	15.6	7.80	18	Yes	12	
28 13:00	.68		48.96	15.0	7.80	18	Yes	12	
29 16:00	.79		56.88	15.3	7.80	18	Yes	12	
30 12:05	.84			15.7	7.80	18	Yes	12	
31 /									

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.