

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **OCTOBER 2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.07			.07
2				.06			.07
3				.07			.12
4				.07			.08
5				.08			.08
6				.09			.09
7				.10			.10
8				.10			.10
9				.12			.12
10				.10			.10
11				.10			.10
12				.10			.10
13				.44			.10
14				.15			.16
15				.15			.15
16				.16			.16
17				.16			.16
18				.16			.16
19				.05			.06
20				.06			.07
21				.06			.06
22				.06			.07
23				.07			.07
24				.07			.07
25				.07			.07
26				.07			.07
27				.07			.07
28				.07			.07
29				.07			.07
30				.07			.07
31				.08			.08

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	PRINTED NAME: Jeff Burch SIGNATURE: <i>Jeff Burch</i> DATE: 11-10-22 PHONE #: (503) 816-0958 CERT #: 6091		
Notes: On 10/13/22 There was a hiccup on the machine and went back to normal.			

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: October 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 11:45:05	.97	72	69.84	15.6	7.80	18	Yes	12
2 12:35	.88		63.36	15.3	7.80	18	Yes	12
3 1:35	.89		64.08	15.5	7.80	18	Yes	12
4 2:05	.91		65.52	15.2	7.90	18	Yes	12
5 1:13:05	.83		59.76	15.0	7.90	18	Yes	12
6 1:40:50	.62		44.64	15.0	7.90	18	Yes	12
7 1:40:05	.78		56.16	15.2	7.80	18	Yes	12
8 1:44:05	.91		65.52	15.4	7.80	18	Yes	12
9 1:49:55	.74		53.28	15.0	7.80	18	Yes	12
10 1:49:00	.81		58.32	15.1	7.80	18	Yes	12
11 1:5:30	.88		63.36	14.9	7.80	18	Yes	12
12 1:3:00	.93		66.96	15.6	7.80	18	Yes	12
13 1:19:30	.84		60.48	15.1	7.80	18	Yes	12
14 1:00:00	.71		51.12	15.0	7.90	18	Yes	12
15 1:19:30	.84		60.48	15.3	7.90	18	Yes	12
16 1:5:45	.97		69.84	15.7	7.90	18	Yes	12
17 1:13:35	.82		59.04	15.6	7.90	18	Yes	12
18 1:11:35	.75		54	15.6	7.90	18	Yes	12
19 1:11:45	.71		51.12	15.5	7.90	18	Yes	12
20 1:11:05	.79		56.88	15.4	7.90	18	Yes	12
21 1:18:45	.98		70.56	15.2	7.90	18	Yes	12
22 1:13:35	.95		68.4	15.2	7.80	18	Yes	12
23 1:19:35	.80		57.6	13.0	7.90	26	Yes	12
24 1:00:00	.76		54.72	13.7	7.80	26	Yes	12
25 1:1:30	.87		62.64	13.5	7.80	26	Yes	12
26 1:18:30	.80		57.6	13.4	7.80	26	Yes	12
27 1:18:45	.67		48.24	13.1	7.80	26	Yes	12
28 1:17:00	.70		50.4	13.7	7.80	26	Yes	12
29 1:15:30	.73		52.56	13.2	7.80	26	Yes	12
30 1:17:00	.67		48.24	13.9	7.80	26	Yes	12
31 1:10:05	.90		64.8	14.0	7.80	26	Yes	12

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.