

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: FEBRUARY 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.01			.01
2				.01			.01
3				.01			.01
4				.01			.01
5	PLANT UNDER CIP MAINTENANCE						
6				.01			.01
7				.01			.01
8				.01			.01
9				.01			.01
10				.01			.01
11				.01			.01
12				.01			.01
13				.03			.03
14				.03			.03
15				.03			.03
16				.03			.03
17				.03			.03
18				.03			.03
19				.03			.03
20				.03			.03
21				.03			.03
22				.03			.07
23				.07			.08
24				.07			.07
25				.11			.11
26				.10			.10
27				.10			.10
28	power outage						
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Burch	DATE: 3-8-23
	SIGNATURE: <i>[Signature]</i>	CERT #: 6091
	PHONE #: (503) 816-0958	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: FEBRUARY 2023

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/16/23	.91	72	65.52	9.2	7.90	35	Yes	10
2/16/23	.88		63.36	8.5	7.90	35	Yes	10
3/17/23	.76		54.72	8.4	7.90	35	Yes	10
4/16/23	.70		50.4	8.9	7.90	35	Yes	10
5/1	PLANT	UNDER	CIP	MAINTENANCE				10
6/1/23	.76		54.72	8.9	7.90	35	Yes	10
7/1/23	.71		51.12	9.2	7.90	35	Yes	10
8/1/23	.70		50.4	9.0	7.90	35	Yes	10
9/2/23	.99		71.28	9.3	7.90	36	Yes	10
10/1/23	.95		68.4	9.5	7.90	36	Yes	10
11/1/23	.90		64.8	8.9	7.90	36	Yes	10
12/20/23	.81		58.32	8.9	7.90	35	Yes	10
13/1/23	.87		62.64	9.0	7.90	35	Yes	10
14/1/23	.81		58.32	8.7	7.90	35	Yes	10
15/1/23	.63		45.36	8.9	7.90	35	Yes	10
16/1/23	.76		54.72	9.4	7.90	36	Yes	10
17/1/23	.80		57.6	8.9	7.90	35	Yes	10
18/1/23	.88		63.36	8.8	7.90	35	Yes	10
19/1/23	.88		63.36	9.6	7.90	36	Yes	10
20/1/23	.96		69.12	9.3	7.90	36	Yes	10
21/1/23	.91		65.52	9.3	7.90	36	Yes	10
22/1/23	.89		64.08	8.1	7.90	36	Yes	10
23/1/23	.80		57.6	7.2	7.90	35	Yes	10
24/1/23	1.10		79.2	7.8	7.90	36	Yes	10
25/1/23	1.03		74.16	7.0	7.90	36	Yes	10
26/1/23	1.00		72	7.3	7.90	36	Yes	10
27/1/23	1.04		74.88	7.9	7.90	36	Yes	10
28/1	power			outage				10
29/1								
30/1								
31/1								

³If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day