

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: TIMBER WATER ASSOCIATION ID #: OR4100898 WTP:- WTP-A Month/Year: JUNE 2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1				.04			.05	
2				.04			.05	
3				.04			.04	
4				.05			.05	
5				.07			.13	
6				.07			.07	
7				.05			.06	
8				.06			.06	
9	power outage							
10				.06			.10	
11				.21			.21	
12				.04			.08	
13				.04			.04	
14				.04			.06	
15				.05			.08	
16				.05			.05	
17				.05			.09	
18			.08	.06			.08	
19				.06			.06	
20				.06			.07	
21				.07			.07	
22				.07			.07	
23				.08			.08	
24				.08			.08	
25				.09			.09	
26				.09			.10	
27				.10			.12	
28				.13			.13	
29				.13			.14	
30				.14			.14	
31				.14			.15	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Jeff Bureh	DATE: 7-6-23
		SIGNATURE: <i>Jeff Bureh</i>	CERT #: 6091
		PHONE #: 1503 1816-0958	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: JUNE 2023

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 11:35	.76	72	54.72	14.5	7.90	26	Yes	12
2 11:55	.69		49.68	14.9	7.90	26	Yes	12
3 11:05	.71		51.12	14.5	7.90	26	Yes	12
4 11:35	.62		44.64	14.1	7.90	26	Yes	12
5 11:00	.83		59.76	14.1	7.90	26	Yes	10
6 12:00	.89		64.08	14.7	7.90	26	Yes	10
7 10:30	.94		67.68	14.5	7.90	26	Yes	10
8 11:00	.97		69.84	14.3	7.90	26	Yes	10
9	power			outage				10
10 11:30	.87		63.64	14.1	7.80	26	Yes	10
11 11:30	.90		64.8	14.4	7.80	26	Yes	10
12 12:05	.61		43.92	15.6	7.90	17	Yes	12
13 11:05	.88		63.36	15.2	7.80	18	Yes	12
14 11:45	.99		71.28	15.0	7.90	18	Yes	12
15 11:05	1.05		75.6	14.8	7.90	27	Yes	12
16 11:05	.98		70.56	14.3	7.90	27	Yes	12
17 11:05	.96		69.12	13.7	7.90	27	Yes	12
18 11:35	.94		67.68	13.9	7.90	27	Yes	12
19 12:30	.97		69.84	13.5	7.90	27	Yes	12
20 10:30	.99		71.28	13.8	7.80	27	Yes	12
21 Dec 00	.81		58.32	14.2	7.80	27	Yes	12
22 11:00	.78		56.16	14.7	7.80	27	Yes	12
23 Dec 00	.83		59.76	15.0	7.80	18	Yes	12
24 11:30	.92		66.24	15.2	7.80	18	Yes	12
25 11:30	.99		71.28	15.7	7.90	18	Yes	12
26 11:05	.82		59.04	16.1	7.90	18	Yes	12
27 11:05	1.01		72.72	16.3	7.90	18	Yes	12
28 11:45	1.00		72	16.1	7.90	18	Yes	12
29 11:35	.96		69.12	15.8	7.90	18	Yes	12
30 11:05	.80	✓	57.6	15.6	7.80	18	Yes	12
31 /								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.