

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **August/2023**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1				.28			.29	
2				.30			.32	
3	PLANT SHUTDOWN							
4				.40			.40	
5				.50			.65	
6				.91			.96	
7				.38			.38	
8				.32			.32	
9				.29			.29	
10				.27			.27	
11				.26			.26	
12				.25			.25	
13				.24			.26	
14				.12			.12	
15				.10			.11	
16				.08			.08	
17				.08			.08	
18				.06			.08	
19	PLANT IN MAINTENANCE							
20				.18			.18	
21				.85			.85	
22				.73			.73	
23				.64			.64	
24				.58			.58	
25				.55			.55	
26				.53			.53	
27				.52			.52	
28				.27			.27	
29				.07			.28	
30				.28			.28	
31				.20			.30	

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Jeff Burch	DATE: 9-10-23
		SIGNATURE: <i>[Signature]</i>	CERT #: 6091
		PHONE #: 503 1816-0958	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP-: WTP-A Month/Year: August/2003

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1 16:30	.93	72	66.96	18.0	7.80	18	Yes	12
2 19:00	.87		62.04	18.5	7.80	18	Yes	12
3 1	PLANT		SHUT DOWN					12
4 14:05	.89		64.08	17.9	7.70	18	Yes	12
5 122:50	.76		54.72	18.1	7.80	18	Yes	12
6 120:35	.69		49.68	18.1	7.80	18	Yes	12
7 17:00	.80		57.6	18.2	7.80	18	Yes	12
8 18:00	.86		61.92	18.5	7.80	18	Yes	12
9 18:00	.89		64.08	17.9	7.80	18	Yes	12
10 19:40	.93		66.96	18.0	7.80	18	Yes	12
11 17:00	.98		70.56	17.6	7.80	18	Yes	13
12 13:00	1.00		72	17.8	7.80	18	Yes	13
13 14:30	.73		52.56	18.5	7.80	18	Yes	13
14 17:05	.81		58.32	18.7	7.80	18	Yes	13
15 16:30	.78		56.16	18.9	7.80	18	Yes	13
16 12:20	.75		54	18.3	7.80	18	Yes	13
17 10:40	.82		59.04	18.5	7.80	18	Yes	15
18 120:45	.94		67.68	18.8	7.80	18	Yes	15
19 1	NO TEST		RAN MAINTENANCE					15
20 16:05	.91		65.52	18.0	7.80	18	Yes	15
21 11:30	.93		66.96	17.6	7.80	18	Yes	12
22 15:30	.80		57.6	17.0	7.80	18	Yes	12
23 00:00	.99		71.28	16.8	7.80	18	Yes	12
24 19:30	1.03		74.16	18.0	7.80	18	Yes	12
25 9:30	1.05		75.6	17.1	7.80	18	Yes	12
26 11:00	1.10		79.2	17.9	7.80	18	Yes	12
27 17:50	.70		50.4	18.7	7.80	18	Yes	12
28 17:45	.90		64.8	18.3	7.80	18	Yes	12
29 16:35	.86		61.92	18.1	7.80	18	Yes	12
30 14:05	.79		56.88	17.9	7.80	18	Yes	12
31 14:05	.71		51.12	17.7	7.80	18	Yes	12

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.