

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **January - 2024**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.05			.11
2				.01			.02
3				.01			.01
4				.01			.02
5				.12			.22
6				.03			.11
7				.03			.08
8				.03			.03
9							
10							
11							
12				.04			.04
13				.05			.05
14				.05			.05
15				.05			.06
16				.05			.06
17							
18							
19				.05			.06
20				.06			.06
21				.07			.07
22				.07			.07
23				.07			.07
24				.08			.08
25				.08			.09
26				.09			.09
27				.10			.10
28				.11			.11
29				.12			.12
30				.13			.13
31				.13			.13

power pump

outage outage

NO WORK TODAY

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Burch	
	SIGNATURE: <i>[Signature]</i>	DATE: 2-9-24
	PHONE #: (503) 816-0958	CERT #: 6091

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: January - 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/7/25	.78	72	56.16	10.7	7.90	26	Yes	10
2/7/05	.74		53.28	10.7	7.90	26	Yes	10
3/10/25	.70		50.4	10.6	7.90	26	Yes	10
4/10/35	.69		49.68	10.4	7.90	26	Yes	10
5/12/10	.60		43.2	10.6	7.90	26	Yes	10
6/19/30	.66		47.52	10.5	7.90	26	Yes	10
7/18/30	.64		46.08	10.2	7.80	26	Yes	10
8/18/30	.83		59.76	10.1	7.90	26	Yes	10
9/1	Power out			cut off				10
10/1	Power out			cut off				10
11/19/30	.82		59.04	10.8	7.90	36	Yes	10
12/14/00	.89		64.08	10.0	7.90	26	Yes	10
13/1/30	1.11		79.92	8.5	7.80	36	Yes	10
14/1/00	1.08		77.76	7.8	7.80	36	Yes	10
15/13/05	.97		69.84	7.7	7.90	36	Yes	10
16/10/35	.80		57.6	7.5	7.90	35	Yes	10
17/1		NO	WORK			TODAY		10
18/20/40	.97		69.84	7.0	7.90	36	Yes	10
19/10/05	1.00		72	8.2	7.90	36	Yes	10
20/12/35	1.05		75.6	9.5	7.80	36	Yes	10
21/11/05	1.03		74.16	9.9	7.80	36	Yes	10
22/12/00	.85		61.2	9.6	7.80	36	Yes	10
23/1/00	.81		58.32	10.7	7.80	26	Yes	10
24/1/00	.78		56.16	10.5	7.80	26	Yes	10
25/1/00	.87		62.64	10.7	7.80	26	Yes	10
26/1/00	.89		64.08	10.2	7.80	26	Yes	10
27/1/00	.82		66.24	10.8	7.80	27	Yes	10
28/1/00	1.05		75.6	10.9	7.80	27	Yes	10
29/1/00	1.00		72	10.7	7.80	27	Yes	10
30/1/05	.96		69.12	10.7	7.80	27	Yes	10
31/1/45	.94		67.68	10.5	7.80	27	Yes	10

If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day