

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP-: **WTP-A** Month/Year: **April/2024**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				.03			.03
2				.03			.03
3				.03			.03
4				.05			.05
5				.03			.03
6				.03			.03
7				.03			.03
8				.03			.04
9				.03			.03
10				.03			.04
11				.04			.04
12				.04			.04
13				.04			.04
14				.04			.04
15				.04			.04
16				.04			.04
17				.04			.04
18				.04			.04
19				.04			.05
20				.05			.05
21				.05			.06
22				.06			.06
23				.07			.07
24				.08			.08
25				.08			.09
26				.09			.09
27			power		outage		
28				.10			.10
29				.11			.11
30				.36			.36
31							

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="checkbox"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Jeff Burch	DATE: 5-14-24
	SIGNATURE: <i>[Signature]</i>	CERT #: 6091
	PHONE #: (503) 816-0958	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program – Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4100898 WTP: WTP-A Month/Year: Apr 1/2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/16:30	1.10	72	79.2	11.5	7.80	27	Yes	10
2/13:00	1.12		80.64	11.8	7.80	27	Yes	10
3/16:00	1.10		79.2	11.2	7.80	27	Yes	10
4/13:30	.98		76.56	11.3	7.80	27	Yes	10
5/17:00	.96		69.12	11.5	7.80	27	Yes	10
6/15:00	1.00		72	11.6	7.80	27	Yes	10
7/15:00	.72		51.84	11.8	7.80	27	Yes	10
8/18:35	.76		54.72	11.9	7.80	26	Yes	10
9/19:45	.70		50.4	12.4	7.80	26	Yes	10
10/10:55	.78		56.16	12.6	7.80	26	Yes	10
11/15:35	.75		54	12.8	7.80	26	Yes	10
12/18:35	.71		51.12	12.8	7.80	26	Yes	10
13/15:45	.99		71.28	12.8	7.80	27	Yes	10
14/14:00	1.00		72	12.6	7.80	27	Yes	10
15/13:00	.90		64.8	12.3	7.80	27	Yes	10
16/9:00	1.02		73.44	12.5	7.80	27	Yes	10
17/15:00	.92		66.24	12.1	7.80	27	Yes	10
18/13:00	.72		51.84	12.9	7.80	27	Yes	10
19/15:30	.89		64.08	12.8	7.80	27	Yes	10
20/15:30	1.08		77.76	12.0	7.80	27	Yes	10
21/14:30	.78		56.16	11.8	7.80	27	Yes	10
22/18:00	.90		64.8	12.3	7.80	27	Yes	10
23/16:30	1.08		77.76	12.7	7.80	27	Yes	10
24/12:30	1.10		79.2	12.2	7.90	27	Yes	10
25/16:30	.78		56.16	12.0	7.90	27	Yes	10
26/15:30	.83		59.76	11.5	7.80	26	Yes	10
27/1			Outage					10
28/7:30	.85		61.2	11.3	7.80	26	Yes	10
29/9:00	.90		64.8	11.6	7.90	26	Yes	10
30/13:00	.63		45.36	11.8	7.90	26	Yes	10
31/1								

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWP by end of next business day.