

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Washington
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **TIMBER WATER ASSOCIATION** ID #: **OR4100898** WTP: **WTP-A** Month/Year: **APRIL-2025**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1				.07			.08
2				.07			.07
3				.08			.08
4				.08			.08
5				.08			.09
6				.08			.08
7				.09			.09
8			power power / plant		outage problems		
9							
10				.10			.10
11				.10			.10
12				.10			.11
13				.11			.16
14				.11			.11
15				.11			.11
16				.12			.12
17							
18		PLANT		SHUTDOWN			
19				.04			.04
20				.04			.04
21				.02			.02
22				.07			.07
23				.02			.02
24				.02			.02
25				.02			.02
26				.02			.02
27				.02			.03
28				.03			.03
29				.03			.04
30		PLANT SHUTDOWN		INLET PRESSURE			HI-HI
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No	All daily turbidity readings ≤ 5 NTU? ☒ Yes / ☐ No	CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No
Notes:		PRINTED NAME: Jeff Burch	
		SIGNATURE: [Signature]	DATE: 5-9-25
		PHONE #: 503 1816-0958	CERT #: 6091

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. Filtered Systems only

OHA - Drinking Water Program - Surface Water Quality Data Form

TIMBER WATER ASSOCIATION ID #: OR4188298 WTP: WTP-A Month/Year: APRIL 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1 4/6/05	.87	72	62.64	11.9	7.80	26	Yes	10
2 1/13/45	.99		71.28	12.2	7.80	27	Yes	10
3 1/15/45	.98		70.56	12.3	7.80	27	Yes	10
4 1/17/05	.96		69.12	12.5	7.80	27	Yes	10
5 1/10/35	.94		67.68	11.9	7.80	26	Yes	10
6 1/20/45	.90		64.80	11.9	7.80	26	Yes	10
7 1/12/00	1.11		75.92	12.3	7.80	27	Yes	10
8 /	power			cut a/c				10
9 /	power / plant			problems				10
10 1/1/00	.84		60.48	11.9	7.80	26	Yes	8
11 1/1/30	.90		64.80	12.2	7.80	26	Yes	8
12 1/1/00	.94		67.68	12.0	7.80	27	Yes	8
13 1/1/00	.80		57.6	11.9	7.80	26	Yes	8
14 1/18/45	.88		63.36	13.1	7.80	26	Yes	8
15 1/15/50	.81		58.32	13.5	7.80	26	Yes	8
16 1/12/05	.79		56.88	13.8	7.80	26	Yes	8
17 1/16/40	.76		54.72	13.6	7.80	26	Yes	8
18 /	PLANT			SHUT DOWN				
19 1/17/20	.66		47.52	12.5	7.80	26	Yes	8
20 1/21/05	1.02		73.44	12.3	7.80	27	Yes	8
21 1/18/30	1.11		79.92	12.0	7.80	27	Yes	8
22 1/10/00	1.12		80.64	11.9	7.80	27	Yes	10
23 1/10/30	1.10		79.2	12.2	7.80	27	Yes	10
24 1/10/00	.81		58.32	12.3	7.80	27	Yes	10
25 1/18/00	.85		61.2	12.5	7.80	27	Yes	10
26 1/15/30	.80		57.6	12.5	7.80	27	Yes	10
27 1/15/00	.63		45.36	12.0	7.80	27	Yes	10
28 1/12/35	.80		57.6	13.0	7.80	26	Yes	10
29 1/17/05	.78		56.16	13.5	7.80	26	Yes	10
30 /	PLANT			SHUTDOWN INLET PRESSURE HI-HI				
31 /								

³ If Cl₂ entry point < 0.2 mg/L OR CT not met, notify DWP by end of next business day
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-all-unfiltered.p