

OHA - DWS

Membrane Filter Monthly Operating Report

County: WASHINGTON

System Name: TIMBER WATER ASSOCIATION Month/Year: DECEMBER 2025
 PWS ID#: 41 - 00898 Minimum test pressure applied || req'd: 20 psi || 17.8 psi
 Plant ID: WTP - _____ (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [^{psi}/_{min}]

LRC [log removal]

.114

4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [^{psi} / _{min}]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	.033		N/A	.053		Y
2	.030		N/A	.054		Y
3	.037		N/A	.054		Y
4	.040		N/A	.046		Y
5	.039		N/A	.046		Y
6	.040		N/A	.044		Y
7	.037		N/A	.046		Y
8	.051		N/A	.050		Y
9	.049		N/A	.058		Y
10	.048		N/A	.064		Y
11	.046		N/A	.084		Y
12	.051		N/A	.072		Y
13	.053		N/A	.065		Y
14	.049		N/A	.041		Y
15	.050		N/A	.054		Y
16	.049		N/A	.041		Y
17	POWER		OUTAGE	-	-	OFF
18	"		"	-	-	OFF
19	.051		N/A	.049		Y
20	PLANT		CLEANING	-	-	OFF
21	.048		N/A	.050		Y
22	POWER		OUTAGE	-	-	OFF
23	.051		N/A	.041		Y
24	.055		N/A	.041		Y
25	.058		N/A	.060		Y
26	.062		N/A	.054		Y
27	.060		N/A	.055		Y
28	.053		N/A	.054		Y
29	.051		N/A	.101		Y
30	.053		N/A	.100		Y
31	PLANT		MAINTENANCE	-	-	OFF

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N] <p style="text-align: center;">Yes</p>	All turbidity readings ≤ 5 NTU? [Y/N] <p style="text-align: center;">Yes</p>	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC) <p style="text-align: center;">yes</p>	DIT Daily? <p style="text-align: center;">Y</p>
CT's met daily? (p. 2) <p style="text-align: center;">Y</p>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <p style="text-align: center;">Y</p>	PDR ≤ PDR _{Max} ? <p style="text-align: center;">Y</p>	LRV _{ambient} ≥ LRC?	

PRINTED NAME: CHRIS RICHARDSON

SIGNATURE:

Notes: Resubmitted due to typo data entry error

DATE: 3-16-26

WT CERT #: 888483

PHONE #: 503-778-0252