

OHA - DWS

Membrane Filter Monthly Operating Report

County: WASHINGTON

System Name: TIMBER WATER ASSOCIATION

Month/Year: JANUARY 2026

PWS ID#: 41-00898

Minimum test pressure applied || req'd: 20 psi || 17.8 psi

Plant ID: WTP (e.g. "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇄

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{min} [¹/_{min}]

LRC [log removal]

.114

4.80

DIT Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [¹ / _{min}]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	.050		N/A	.088		Yes
2	.056		N/A	.089		Yes
3	.059		N/A	.088		Yes
4	CLEANING			N/A IN PLACE		OFF
5	.065		N/A	.041		Yes
6	.040		N/A	.045		Yes
7	.036		N/A	.040		Yes
8	.030		N/A	.046		Yes
9	.025		N/A	.048		Yes
10	.025		N/A	.037		Yes
11	.025		N/A	.038		Yes
12	.021		N/A	.037		Yes
13	.030		N/A	.035		Yes
14	.031		N/A	.087		Yes
15	.030		N/A	.088		Yes
16	.035		N/A	.090		Yes
17	.027		N/A	.081		Yes
18	.025		N/A	.052		Yes
19	.024		N/A	.053		Yes
20	.020		N/A	.056		Yes
21	.038		N/A	.053		Yes
22	.027		N/A	.046		Yes
23	.024		N/A	.048		Yes
24	.022		N/A	.044		Yes
25	.029		N/A	.045		Yes
26	.024		N/A	.045		Yes
27	.028		N/A	.046		Yes
28	.020		N/A	.043		Yes
29	.024		N/A	.058		Yes
30	.023		N/A	.057		Yes
31	.020		N/A	.028		Yes

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] PDR ≤ PDR _{min} , LRV ≥ LRC	DIT Daily?
Y	Y	N/A	Y	Y
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/l?	PDR ≤ PDR _{min} ?	LRV _{ambient} ≥ LRC?	
Y	Y	Y		

PRINTED NAME: CHRIS RICHARDSON

SIGNATURE: *chr*

Notes:

DATE: 2/6/26

WT CERT #: 888483

PHONE #:

503-778-0252

OHA-DWS

Disinfection Monthly Operating Report

System Name: TIMBER WATER ASSOCIATION

PWS ID# 41- 00898

Plant ID: WTP- _____

Log Inactivation Required via Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C)* [^m % = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [°C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	.79	72	56.88	11.5	7.80	26	Yes	13	IN PRODUCTION
2	.80		57.6	11.9	7.80	26	Yes	13	IN PRODUCTION
3	.84		60.48	12.0	7.80	26	Yes	13	IN PRODUCTION
4	CLEANING IN PLACE								OFF
5	.86		61.92	12.3	7.80	26	Yes	15	IN PRODUCTION
6	.81		58.32	12.3	7.80	26	Yes	15	IN PRODUCTION
7	.84		60.48	11.8	7.80	26	Yes	15	IN PRODUCTION
8	.96		69.12	11.5	7.80	27	Yes	15	IN PRODUCTION
9	.90		64.8	11.3	7.80	26	Yes	15	IN PRODUCTION
10	.83		59.76	11.0	7.80	26	Yes	15	IN PRODUCTION
11	.85		61.2	11.1	7.80	26	Yes	15	IN PRODUCTION
12	.86		61.92	11.5	7.80	26	Yes	15	IN PRODUCTION
13	.90		64.8	11.8	7.80	26	Yes	15	IN PRODUCTION
14	.87		62.64	11.0	7.80	26	Yes	15	IN PRODUCTION
15	.78		56.16	11.5	7.80	26	Yes	15	IN PRODUCTION
16	.76		54.72	11.1	7.80	26	Yes	15	IN PRODUCTION
17	.80		57.6	11.1	7.80	26	Yes	15	IN PRODUCTION
18	.83		59.76	11.0	7.80	26	Yes	15	IN PRODUCTION
19	.79		56.88	10.7	7.80	26	Yes	15	IN PRODUCTION
20	.84		60.48	10.0	7.80	26	Yes	15	IN PRODUCTION
21	.92		66.24	9.3	7.80	35	Yes	15	IN PRODUCTION
22	.96		69.12	8.6	7.80	36	Yes	15	IN PRODUCTION
23	.89		64.08	8.2	7.80	35	Yes	15	IN PRODUCTION
24	.82		59.04	7.9	7.80	35	Yes	15	IN PRODUCTION
25	.75		54	7.7	7.80	35	Yes	15	IN PRODUCTION
26	.78		56.16	7.5	7.80	35	Yes	15	IN PRODUCTION
27	.80		57.6	7.8	7.80	35	Yes	15	IN PRODUCTION
28	.69		47.64	7.7	7.80	35	Yes	15	IN PRODUCTION
29	.70		50.4	8.3	7.80	35	Yes	15	IN PRODUCTION
30	.74		53.28	8.7	7.80	35	Yes	15	IN PRODUCTION
31	.79		56.88	9.5	7.80	35	Yes	15	IN PRODUCTION

* If chlorine concentration at entry point < 0.2 ^m%, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350
email: gen.dince@odhseoha.oregon.gov
fax: 971-673-0458