

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: TIMBER WATER ASSOCIATION County: WASHINGTON  
 PWS ID#: 41 - 00898 Month/Year: MARCH - 2026  
 Plant ID: WTP - \_\_\_\_\_ (e.g. "A") Minimum test pressure applied || req'd: 20 psi || 17.8 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌  
 PDR = Pressure Decay Rate PDR<sub>max</sub> [<sup>psi</sup>/min] LRC [log removal]  
 LRC = Log Removal Credit .114 4.00

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [ <sup>psi</sup> /min]	Lowest LRV <sub>ambient</sub> of day [log removal]	DIT Daily [Y/N] or "off"
1	.040		N/A	.044		Yes
2	.031		N/A	.046		Yes
3	.081		N/A	.044		Yes
4	.064		N/A	.048		Yes
5	.044		N/A	.051		Yes
6	.061		N/A	.056		Yes
7	.038		N/A	.069		Yes
8	.040		N/A	.081		Yes
9	.041		N/A	.080		Yes
10	.040		N/A	.081		Yes
11	.036		N/A	.079		Yes
12	POWER OUTAGE					OFF
13	.030		N/A	.029		Yes
14	.032		N/A	.033		Yes
15	.035		N/A	.029		Yes
16	.037		N/A	.045		Yes
17	.044		N/A	.040		Yes
18	.040		N/A	.042		Yes
19	.042		N/A	.046		Yes
20	.055		N/A	.048		Yes
21	.057		N/A	.050		Yes
22	.053		N/A	.034		Yes
23	CRITICAL PLANT SHUTDOWN					OFF
24	.050		N/A	.033		Yes
25	.053		N/A	.036		Yes
26	.055		N/A	.034		Yes
27	.058		N/A	.030		Yes
28	.060		N/A	.039		Yes
29	.059		N/A	.047		Yes
30	.053		N/A	.041		Yes
31	.050		N/A	.037		Yes

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N] <b>Yes</b>	All turbidity readings ≤ 5 NTU? [Y/N] <b>Yes</b>	All IFE turbidity readings ≤ 0.15 NTU? [Y/N] <b>N/A</b>	Performance std met? [Y/N] (PDR ≤ PDR <sub>max</sub> , LRV ≥ LRC) <b>Y</b>	DIT Daily? <b>Y</b>
CT's met daily? (p. 2) <b>Yes</b>	All Cl <sub>2</sub> residual at EP ≥ 0.2 mg/L? <b>Yes</b>	PDR ≤ PDR <sub>max</sub> ? <b>Y</b>	LRV <sub>ambient</sub> ≥ LRC? <b>N/A</b>	

PRINTED NAME: CHRIS RICHARDSON DATE: 4-9-26  
 SIGNATURE: CHR WT CERT #: 888483  
 Notes: PHONE #: 503-778-0252

OHA-DWS

Disinfection Monthly Operating Report

System Name: TIMBER WATER ASSOCIATION

PWS ID#: 41 - 00898

Plant ID : WTP - \_\_\_\_\_

Log Inactivation Required via Disinfection

Day	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [°C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	.90	72	64.8	11.3	7.80	26	Yes	15	IN PRODUCTION
2	.96		69.12	11.3	7.80	27	Yes	15	IN PRODUCTION
3	.95		68.4	11.0	7.80	27	Yes	15	IN PRODUCTION
4	.93		66.96	10.9	7.80	26	Yes	15	IN PRODUCTION
5	.87		62.62	11.1	7.80	26	Yes	15	IN PRODUCTION
6	.85		61.2	11.3	7.80	26	Yes	15	IN PRODUCTION
7	.82		59.04	11.2	7.80	26	Yes	15	IN PRODUCTION
8	.80		57.6	11.2	7.80	26	Yes	15	IN PRODUCTION
9	.83		59.76	11.3	7.80	26	Yes	10	IN PRODUCTION
10	.85		61.2	10.9	7.80	26	Yes	10	IN PRODUCTION
11	.89		64.08	10.8	7.80	26	Yes	10	IN PRODUCTION
12	POWER		OUTAGE						OFF
13	.91		65.52	11.0	7.80	26	Yes	10	IN PRODUCTION
14	.93		66.96	11.3	7.80	26	Yes	10	IN PRODUCTION
15	.86		61.92	11.6	7.80	26	Yes	10	IN PRODUCTION
16	.88		63.36	11.8	7.80	26	Yes	10	IN PRODUCTION
17	.85		61.2	11.5	7.80	26	Yes	10	IN PRODUCTION
18	.77		55.44	12.1	7.80	26	Yes	10	IN PRODUCTION
19	.89		64.08	12.4	7.80	26	Yes	10	IN PRODUCTION
20	.90		64.8	11.9	7.80	26	Yes	10	IN PRODUCTION
21	.90		64.8	11.6	7.80	26	Yes	10	IN PRODUCTION
22	.87		62.62	11.0	7.80	26	Yes	10	IN PRODUCTION
23	CRITICAL		PLANT		SHUTDOWN				OFF
24	.85		61.2	11.5	7.80	26	Yes	10	IN PRODUCTION
25	.89		64.08	11.3	7.80	26	Yes	10	IN PRODUCTION
26	.93		66.96	11.6	7.80	26	Yes	10	IN PRODUCTION
27	.95		68.4	11.9	7.80	27	Yes	10	IN PRODUCTION
28	.90		64.8	12.1	7.80	26	Yes	10	IN PRODUCTION
29	.92		66.24	12.0	7.80	26	Yes	10	IN PRODUCTION
30	.94		67.68	12.2	7.80	26	Yes	10	IN PRODUCTION
31	.89	✓	64.08	11.4	7.80	26	Yes	10	IN PRODUCTION

\* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10<sup>th</sup> of following month by

mail: Drinking Water Services  
PO Box 14350  
Portland, OR 97293-0350  
email: [dwp\\_dmce@odhsoha.oregon.gov](mailto:dwp_dmce@odhsoha.oregon.gov)  
fax: 971-673-0458