

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln  
Conventional or Direct Filtration**

**System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- A Month/Year: November 2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	.033	.062	.028	.076
2	.083	OFF	OFF	.053	.059	.077	.094
3	.081	OFF	OFF	.038	.076	.083	.095
4	.064	OFF	OFF	.037	.031	.079	.087
5	OFF						
6	OFF						
7	OFF	OFF	OFF	.048	.021	.095	.095
8	OFF	OFF	OFF	.051	.047	.040	.087
9	.035	.042	.055	.064	.077	.089	.096
10	.073	.062	.049	.074	.096	.088	.096
11	.084	.075	.066	.060	.061	.037	.093
12	OFF	OFF	OFF	.051	.033	.028	.068
13	.018	.017	.075	OFF	OFF	OFF	.075
14	OFF	OFF	.078	.033	.037	.069	.088
15	OFF	OFF	OFF	OFF	.066	.051	.085
16	.043	.035	.039	.030	.033	.042	.050
17	OFF						
18	OFF						
19	OFF						
20	OFF						
21	OFF	OFF	OFF	.062	.097	.076	.097
22	.068	.060	.055	.044	.032	.048	.081
23	OFF	OFF	OFF	.090	.022	.031	.093
24	.024	.024	.027	.036	.049	.033	.067
25	.021	.018	.033	.022	.018	.018	.088
26	.024	.029	OFF	.050	.029	.019	.083
27	.018	.017	OFF	OFF	OFF	OFF	.021
28	OFF	OFF	OFF	.018	.023	.033	.054
29	OFF	OFF	.074	.020	.024	.016	.098
30	.016	.021	OFF	OFF	OFF	OFF	.039
31							

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <sup>2</sup>			
<b>Notes:</b>	<b>PRINTED NAME:</b> Rick McClintock		<b>DATE:</b> 12/2/22
	<b>SIGNATURE:</b> <i>Rick McClintock</i>		
	<b>PHONE #:</b> (541) 547-3315		<b>CERT #:</b> 2775

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. A Month/Year: November 2022 Required Log Inactivation: 5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/10:30	1.1	155	171	12	7.4	19.7	Yes	78
2/11:15	1.1	155	171	12	7.4	19.7	Yes	78
3/1:00	1.1	155	171	12	7.5	20.4	Yes	78
4/12:00	1.2	155	186	12	7.5	20.6	Yes	78
5/ off								78
6/ off								78
7/2:00	1.1	155	171	12	7.4	19.7	Yes	83
8/1:15	1.2	155	186	12	7.5	20.6	Yes	83
9/11:00	1.2	155	186	12	7.5	20.6	Yes	83
10/11:30	1.1	155	171	12	7.5	20.4	Yes	83
11/9:00	1.2	155	186	12	7.5	20.6	Yes	83
12/3:00	1.2	155	186	12	7.4	19.9	Yes	83
13/8:15	1.2	155	186	12	7.5	20.6	Yes	83
14/10:30	1.1	155	171	12	7.4	19.7	Yes	83
15/3:00	1.2	155	186	12	7.6	21.3	Yes	83
16/4:50	1.2	155	186	11	7.7	23.6	Yes	83
17/ off								80
18/ off								80
19/ off								80
20/ off								80
21/2:30	1.1	155	171	10	7.6	24.1	Yes	80
22/11:45	1.2	155	186	10	7.7	25.2	Yes	80
23/2:00	1.2	155	186	10	7.7	25.2	Yes	80
24/10:35	1.3	155	202	10	7.7	25.5	Yes	80
25/1:15	1.2	155	186	10	7.6	24.4	Yes	80
26/12:30	1.2	155	186	10	7.6	24.4	Yes	95
27/7:30	1.2	155	186	10	7.6	24.4	Yes	95
28/2:15	1.1	155	171	10	7.5	23.2	Yes	95
29/1:00	1.2	155	186	10	7.6	24.4	Yes	95
30/7:30	1.2	155	186	10	7.6	24.4	Yes	95
31/								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.