


**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- A Month/Year: Feb 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.0FF	OFF	OFF	OFF	.041	.017	.099
2	.016	.016	.018	.018	.019	OFF	.036
3	OFF						
4	OFF						
5	OFF	OFF	OFF	OFF	.028	.026	.058
6	.021	.019	.019	.019	.025	.048	.076
7	.038	.084	OFF	OFF	.020	.017	.087
8	.017	.017	.023	.056	.028	.018	.075
9	.017	.023	OFF	OFF	OFF	OFF	.036
10	OFF						
11	OFF						
12	OFF	OFF	OFF	.053	.020	.017	.080
13	.026	.020	.034	.029	.020	.020	.056
14	.017	.017	.018	.081	.082	OFF	.093
15	OFF	OFF	.019	.033	.087	.051	.095
16	.079	.076	OFF	.048	.020	.030	.090
17	.026	.045	.065	OFF	.047	.019	.078
18	.030	.017	.017	.016	OFF	OFF	.036
19	OFF						
20	OFF						
21	OFF	OFF	OFF	.037	.018	.032	.060
22	.017	.032	.028	.026	.026	.030	.064
23	.036	.040	.044	.032	.020	.018	.053
24	.018	.017	.016	.023	.040	.016	.075
25	OFF						
26	OFF						
27	OFF	OFF	OFF	OFF	.046	.038	.068
28	.034	.027	.018	.018	.017	.016	.036
29	.019	OFF	.064	.085	.045	.023	.095
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Notes:	
Notes:		PRINTED NAME: Zach Forcier	DATE: 3/8/24
Notes:		SIGNATURE: 	CERT #: F-9253
Notes:		PHONE #: (541) 1547-3315	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. Month/Year: **Feb 2024**

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/3:00	1.0	155	155	10	7.6	23.8	Yes	106
2/8:30	1.1	155	171	10	7.6	24.1	Yes	106
3/ off								106
4/ off								106
5/3:00	1.1	155	171	10	7.7	25.0	Yes	106
6/9:00	1.1	155	171	10	7.7	25.0	Yes	106
7/3:30	1.2	155	186	10	7.6	24.4	Yes	106
8/8:30	1.1	155	171	10	7.6	24.1	Yes	106
9/7:30	1.1	155	171	10	7.7	25.0	Yes	106
10/ off								115
11/ off								115
12/2:30	1.1	155	171	10	7.7	25.0	Yes	115
13/8:30	1.0	155	155	10	7.6	23.8	Yes	115
14/8:00	1.1	155	171	10	7.6	24.1	Yes	115
15/1:30	1.1	155	171	10	7.6	24.1	Yes	115
16/3:00	1.2	155	186	10	7.7	25.2	Yes	115
17/8:00	1.1	155	171	10	7.7	25.0	Yes	115
18/8:30	1.1	155	171	10	7.7	25.0	Yes	115
19/ off								103
20/ off								103
21/3:00	1.1	155	171	10	7.7	25.0	Yes	103
22/8:15	1.1	155	171	10	7.7	25.0	Yes	103
23/8:00	1.0	155	155	10	7.6	23.8	Yes	103
24/8:30	1.1	155	171	10	7.6	24.1	Yes	103
25/ off								109
26/ off								109
27/3:30	1.1	155	171	10	7.6	24.1	Yes	109
28/8:30	1.2	155	186	10	7.6	24.4	Yes	109
29/8:30	1.1	155	171	10	7.7	25.0	Yes	109
30/								
31/								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.