

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- A Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF						
2			.024	.018	.021	.020	.043
3	.019	.019	.019	.019	.024	.021	.056
4	.021	.019	.026	.019	.022	.027	.040
5	.024	OFF	.028	.026	.028	.026	.066
6	OFF	OFF	OFF	.025	.024	.025	.086
7	OFF	OFF	OFF	OFF	OFF	OFF	
8	OFF	OFF	OFF	.024	.021	.023	.064
9	OFF	OFF	.038	.053	.027	.023	.058
10	.024	OFF	OFF	.021	.022	.021	.037
11	.023	OFF	OFF	.025	.032	.023	.089
12	.023	.025	.033	.022	OFF	OFF	.062
13	.029	.033	.020	.019	.020	.021	.035
14	OFF	OFF	OFF	OFF	OFF	OFF	
15	OFF	OFF	OFF	OFF	OFF	OFF	
16	OFF	OFF	OFF	OFF	OFF	.027	.048
17	.020	.019	.020	.019	.020	.021	.026
18	.020	.019	.021	.023	.020	.022	.039
19	.023	.024	.025	.025	.027	.031	.035
20	.035	OFF	.027	.027	.026	.038	.116
21	OFF	OFF	OFF	OFF	OFF	OFF	
22	OFF	OFF	OFF	OFF	.067	.041	.123
23	.094	.096	.034	.027	.029	.020	.110
24	.019	.018	.018	.023	OFF	.075	.137
25	.025	.019	OFF	.022	.017	.018	.030
26	OFF	OFF	.022	.023	.025	.030	.098
27	.018	.017	.019	.017	.034	.031	.048
28	OFF	OFF	OFF	OFF	OFF	OFF	
29	OFF	OFF	OFF	.021	.024	.027	.044
30	.019	.020	.020	.018	.019	.018	.086
31							

31				
Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)		
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No		CT's met everyday? (see back) ☒ Yes / ☐ No		All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No
All the 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No				
All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No				
Notes:		PRINTED NAME: Rick McQuay		
		SIGNATURE: R. McQuay		DATE: 7-1-25
		PHONE #: ()		CERT #: 2527

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. A Month/Year: JUNE 2025

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C.X.T	[° C]		Use tables	Yes / No	[GPM]
1 /								120
2 / 10:00	1.2	155	186	14	7.8	20.0	Yes	120
3 / 9:00	1.3	155	202	14	7.7	19.5	Yes	120
4 / 9:00	1.3	155	202	14	7.7	19.5	Yes	120
5 / 9:00	1.4	155	217	14	7.6	19.0	Yes	120
6 / 10:00	1.3	155	202	14	7.7	19.5	Yes	120
7 /								112
8 / 11:00	1.3	155	202	14	7.7	19.5	Yes	112
9 / 9:00	1.2	155	186	14	7.8	20.0	Yes	112
10 / 10:00	1.3	155	202	14	7.6	18.8	Yes	107
11 / 9:00	1.2	155	186	15	7.9	19.4	Yes	107
12 / 9:00	1.3	155	202	15	7.8	18.9	Yes	107
13 / 2:00	1.2	155	186	14	7.5	17.9	Yes	107
14 /								107
15 /								107
16 / 8:00	1.2	155	186	14	7.5	17.9	Yes	107
17 / 11:00	1.3	155	202	14	7.6	18.8	Yes	90
18 / 11:30	1.3	155	202	14	7.7	19.5	Yes	90
19 / 11:00	1.3	155	202	14	7.7	19.5	Yes	90
20 / 10:00	1.3	155	202	14	7.7	19.5	Yes	90
21 /								90
22 / 1:00	1.2	155	186	14	7.6	18.6	Yes	90
23 / 10:00	1.2	155	186	14	7.7	19.3	Yes	134
24 / 9:00	1.2	155	186	14	7.4	17.3	Yes	134
25 / 1:00	1.2	155	186	14	7.5	17.9	Yes	134
26 / 9:00	1.3	155	202	14	7.6	18.8	Yes	134
27 / 9:00	1.3	155	202	14	7.5	18.1	Yes	134
28 /								134
29 / 4:00	1.3	155	202	15	7.6	18.8	Yes	134
30 / 11:00	1.3	155	202	15	7.6	18.8	Yes	134
31 /								

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.