


**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST **ID #:** OR4100925 **WTP:-WTP- A Month/Year:** December 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	.099	.042	.031	.033	.099
2	.036	.040	.039	.023	.034	.043	.075
3	.042	.028	.036	.095	OFF	OFF	.095
4	OFF	OFF	OFF	OFF	OFF	OFF	-
5	OFF	OFF	OFF	OFF	.046	.031	.067
6	OFF	OFF	.049	.028	.018	.020	.080
7	OFF	OFF	.031	.028	.019	.024	.085
8	.021	.015	.015	.017	.019	.015	.062
9	.015	.016	.018	OFF	.036	.034	.118
10	OFF	OFF	.028	.029	.022	.028	.068
11	OFF	OFF	.056	OFF	.043	.017	.082
12	OFF	OFF	OFF	.015	.020	.023	.100
13	OFF	OFF	.021	.020	.023	.025	.104
14	OFF	OFF	OFF	.021	.061	.024	.113
15	.018	.016	.015	.016	.023	OFF	.057
16	OFF	OFF	.086	.025	.022	OFF	.090
17	OFF	OFF	OFF	.018	.017	.017	.075
18	OFF	OFF	OFF	OFF	OFF	OFF	-
19	OFF	OFF	OFF	OFF	OFF	OFF	-
20	OFF	OFF	.084	.038	.028	.023	.097
21	.022	.026	.034	.035	.032	.021	.092
22	.021	.023	.019	.016	.022	.037	.058
23	OFF	OFF	.030	.025	.023	.023	.091
24	OFF	OFF	OFF	.029	.045	.028	.093
25	OFF	OFF	OFF	.019	.018	.016	.075
26	.015	.015	OFF	.018	.025	.018	.086
27	OFF	OFF	OFF	OFF	OFF	OFF	-
28	OFF	OFF	OFF	.016	.015	.015	.077
29	.018	.020	.021	.075	.049	.027	.137
30	OFF	OFF	.019	.022	.047	.031	.078
31	OFF	OFF	.022	.021	.019	.025	.091

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Notes: Rick McClung DRC cert # 2725		PRINTED NAME: Gabe Greenwood SIGNATURE:  DATE: 1-7-26 PHONE #: (808) 1217-7886 CERT #: 2725	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. A Month/Year: December 2025 Required Log Inactivation: .5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C.X.T	[° C]		Use tables	Yes / No	[GPM]
1/9:00	1.5	155	233	12	7.7	21.3	Yes	97
2/11:00	1.4	155	217	12	8.0	25.1	Yes	97
3/8:00	1.4	155	217	12	7.8	23.4	Yes	97
4/								97
5/11:00	1.3	155	202	12	7.9	24.0	Yes	97
6/9:00	1.5	155	233	12	7.8	23.7	Yes	97
7/10:00	1.6	155	248	12	7.6	22.3	Yes	97
8/2:00	1.4	155	217	12	7.8	23.4	Yes	105
9/9:00	1.5	155	233	12	7.7	22.9	Yes	105
10/9:00	1.4	155	217	12	7.7	22.6	Yes	105
11/10:00	1.3	155	202	12	7.5	20.8	Yes	105
12/10:00	1.3	155	202	12	7.6	21.6	Yes	105
13/9:00	1.3	155	202	12	7.7	22.4	Yes	105
14/9:00	1.4	155	217	12	7.7	22.6	Yes	105
15/10:00	1.4	155	217	12	7.7	22.6	Yes	105
16/1:00	1.3	155	202	12	7.9	24.0	Yes	115
17/12:00	1.3	155	202	12	7.9	24.0	Yes	115
18/								115
19/								115
20/12:00	1.3	155	202	12	7.9	24.0	Yes	115
21/12:00	1.3	155	202	12	7.9	24.0	Yes	115
22/10:00	1.4	155	217	12	7.7	22.6	Yes	115
23/9:00	1.5	155	233	12	7.7	21.3	Yes	121
24/9:30	1.2	155	186	12	7.8	24.5	Yes	121
25/11:00	1.4	155	217	12	7.9	24.3	Yes	119
26/9:00	1.3	155	202	11	7.8	24.7	Yes	119
27/								119
28/10:00	1.3	155	202	11	7.7	23.9	Yes	119
29/9:00	1.3	155	202	11	7.7	23.9	Yes	119
30/10:00	1.3	155	202	11	7.7	23.9	Yes	119
31/9:00	1.2	155	186	11	7.6	22.8	Yes	119

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf
 PAGE 2 of 2