

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- A Month/Year: January 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2	off	.070	.088	.064	.026	.020	.091
3							
4							
5	off	off	.021	.017	.035	.057	.104
6	.033	.049	.050	.056	.054	.049	.078
7	.056	.026	.042	.042	.019	.027	.072
8	.020	.022	.023	.019	.028	.032	.105
9	.048	.049	.044	.050	.080	off	.107
10							
11							
12	off	off	off	off	.075	.130	.130
13	.099	.045	.031	.032	.029	.033	.078
14	.026	.028	.028	.028	.037	.063	.075
15	.040	.052	.036	.041	.031	.034	.096
16	.041	.079	.030	.032	.028	.038	.081
17							
18							
19			.033	.033	.044	.037	.090
20	.032	.030	.030	off	.031	.032	.046
21	.032	.043	.061	.081	.053	.041	.092
22	.042	.039	.036	.024	.031	.030	.082
23	.030	.039	off	.027	.062	.045	.083
24							
25							
26	.030	.028	.027	.029	.037	.025	.076
27	.024	.027	.026	.079	.048	.043	.089
28	off	off	.038	.046	.044	.040	.098
29	off	off	off	off	.033	.047	.058
30	off	off	.023	.018	.018	.017	.040
31	off	off	off	off	off	off	off

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No ²			
Notes:	PRINTED NAME: Rick McClung	DATE: 2/3/26	
	SIGNATURE: R. McClung	CERT #: 2725	
	PHONE #: (541) 819-2279		

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. A Month/Year: January 2026

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/1								135
2/10:00	1.3	155	202	10	7.6	24.6	Yes	135
3/								135
4/								135
5/9:00	1.1	155	171	10	7.6	24.1	Yes	125
6/10:00	1.3	155	202	10	7.5	23.8	Yes	125
7/11:00	1.3	155	202	10	7.7	25.5	Yes	125
8/12:00	1.1	155	171	10	7.6	24.1	Yes	73
9/9:00	1.3	155	202	10	7.6	24.6	Yes	73
10/								73
11/								73
12/9:00	1.2	155	186	10	7.2	21.2	Yes	73
13/10:00	1.3	155	202	10	7.8	26.5	Yes	80
14/9:00	1.4	155	217	10	7.7	25.8	Yes	80
15/10:00	1.2	155	186	10	7.8	26.2	Yes	80
16/9:00	1.2	155	186	10	7.7	25.2	Yes	80
17/								80
18/								80
19/11:00	1.2	155	186	10	7.6	24.4	Yes	85
20/9:00	1.1	155	171	10	7.9	26.8	Yes	85
21/12:00	1.2	155	186	10	7.7	25.2	Yes	85
22/10:00	1.3	155	202	10	7.7	25.5	Yes	85
23/9:00	1.3	155	202	10	7.6	24.6	Yes	85
24/								85
25/								85
26/8:00	1.2	155	186	10	7.8	26.2	Yes	91
27/11:00	1.2	155	186	10	7.7	25.2	Yes	91
28/10:00	1.3	155	202	10	7.8	26.5	Yes	91
29/12:00	1.2	155	186	10	7.7	25.2	Yes	91
30/8:00	1.2	155	186	10	7.5	23.5	Yes	91
31/								91

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.