

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- A Month/Year: March 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	-
2	OFF	OFF	.024	.021	.021	.018	.067
3	.016	.018	.018	.015	.018	.025	.069
4	.020	.020	.022	.055	.045	.041	.087
5	OFF	OFF	.036	.021	.025	OFF	.040
6	OFF	OFF	.024	.018	.018	.015	.084
7	OFF	OFF	OFF	OFF	OFF	OFF	-
8	OFF	OFF	OFF	OFF	OFF	OFF	-
9	OFF	OFF	.024	.016	.020	.018	.030
10	OFF	OFF	.030	.023	.015	.015	.047
11	OFF	OFF	OFF	.032	.047	.054	.077
12	OFF	OFF	.064	.053	.046	OFF	.080
13	OFF	OFF	.077	.039	.053	.023	.077
14	OFF	OFF	OFF	OFF	OFF	OFF	-
15	OFF	OFF	OFF	OFF	.019	.018	.095
16	OFF	.041	.077	.063	.059	.043	.099
17	OFF	OFF	.035	.042	.062	.040	.062
18	.034	OFF	OFF	.060	.055	.055	.073
19	OFF	OFF	.038	.035	.032	.033	.065
20	OFF	OFF	.026	.023	.021	.022	.076
21	OFF						
22	OFF	OFF	.024	.019	.019	.018	.104
23	.019	.018	.018	.018	.020	.028	.051
24	OFF	OFF	.024	.018	.016	.016	.042
25	OFF	OFF	.017	.035	.050	.046	.126
26	OFF	OFF	.021	.021	.017	.019	.040
27	OFF	OFF	.017	OFF	.051	.026	.075
28	OFF	OFF	OFF	OFF	OFF	OFF	-
29	OFF	OFF	OFF	OFF	OFF	OFF	-
30	OFF	OFF	.017	.040	.035	OFF	-
31	OFF	OFF	.023				

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes:	PRINTED NAME: <u>Rick McClung</u>	DATE: <u>3/31/26</u>	
	SIGNATURE: <u>R. McClung</u>	CERT #: <u>2725</u>	
	PHONE #: (541) <u>819-2279</u>		

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. A Month/Year: March 2026

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C.X.T	[°C]		Use tables	Yes / No	[GPM]
1/								108
2/9:00	1.2	155	186	10	7.7	25.2	Yes	108
3/8:00	1.3	155	202	10	7.5	23.8	Yes	108
4/8:00	1.4	155	217	10	7.7	24.2	Yes	108
5/7:00	1.3	155	202	10	7.6	24.6	Yes	108
6/12:00	1.3	155	202	10	7.6	24.6		108
7/								108
8/								115
9/8:00	1.3	155	202	10	7.6	24.6	Yes	115
10/9:00	1.3	155	202	10	7.5	23.8	Yes	115
11/11:00	1.2	155	186	10	7.5	23.5	Yes	115
12/9:00	1.2	155	186	10	7.5	23.5	Yes	115
13/10:00	1.3	155	202	10	7.3	22.2	Yes	115
14/								115
15/12:00	1.3	155	202	10	7.3	22.2	Yes	112
16/9:00	1.3	155	202	10	7.3	22.2	Yes	112
17/10:00	1.3	155	202	11	7.4	21.5	Yes	112
18/9:00	1.2	155	186	11	7.4	21.2	Yes	112
19/8:00	1.3	155	202	11	7.6	23.1	Yes	112
20/1:00	1.3	155	202	11	7.9	25.6	Yes	112
21/								112
22/4:00	1.3	155	202	11	7.6	23.1	Yes	106
23/2:00	1.3	155	202	11	7.6	23.1	Yes	106
24/9:00	1.3	155	202	11	7.5	22.3	Yes	106
25/9:00	1.2	155	186	11	7.5	22.6	Yes	110
26/10:00	1.3	155	202	11	7.6	23.1	Yes	110
27/9:00	1.2	155	186	11	7.5	22.6	Yes	110
28/2:00	1.3	155	202	11	7.8	24.7	Yes	110
29/								110
30/10:00	1.3	155	202	11	7.8	24.7	Yes	110
31/9:00	1.3	155	202	11	7.8	24.7	Yes	110

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.