

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST **ID #:** OR4100925 **WTP-:WTP- B** **Month/Year:** January 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF						
2	OFF						
3	OFF						
4	OFF	OFF	OFF	.060	OFF	OFF	.084
5	OFF						
6	OFF						
7	OFF						
8	OFF	OFF	OFF	.044	OFF	OFF	.127
9	OFF						
10	OFF						
11	OFF	OFF	OFF	.052	OFF	OFF	.089
12	OFF						
13	OFF						
14	OFF						
15	OFF						
16	OFF						
17	OFF						
18	OFF						
19	OFF						
20	OFF						
21	OFF						
22	OFF						
23	OFF						
24	OFF						
25	OFF	OFF	OFF	.098	OFF	OFF	.248
26	OFF						
27	OFF						
28	OFF						
29	OFF	OFF	OFF	.052	OFF	OFF	.150
30	OFF						
31	OFF						

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? (Yes/No)	CT's met everyday? (see back) (Yes/No)	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? (Yes/No)	
All the 4-hour turbidity readings ≤ 1 NTU? (Yes/No)			
All turbidity readings < IFE ² triggers? (Yes/No)			
Notes: RECEIVED FEB 11 2021 Data Mgmt & Compliance Drinking Water Program	PRINTED NAME: BARRY ARNOLD		
	SIGNATURE: Barry Arnold	DATE: 2-4-21	
	PHONE #: (541) 547-4951	CERT #: 3636	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-B Month/Year: January 2021 Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1 / OFF								31
2 / OFF								31
3 / OFF								31
4 / 11:30	1.1	105	116	10°	7.7	25.0	Yes	31
5 / OFF								31
6 / OFF								31
7 / OFF								31
8 / 1:00	1.1	105	116	10°	7.7	25.0	Yes	31
9 / OFF								54
10 / OFF								54
11 / 11:30	1.1	105	116	10°	7.7	25.0	Yes	54
12 / OFF								54
13 / OFF								54
14 / OFF								54
15 / OFF								54
16 / OFF								54
17 / OFF								54
18 / OFF								18
19 / OFF								18
20 / OFF								18
21 / OFF								18
22 / OFF								18
23 / OFF								18
24 / OFF								18
25 / 1:00	1.2	105	126	10°	7.9	27.1	Yes	26
26 / OFF								26
27 / OFF								26
28 / OFF								26
29 / 1:00	1.0	105	105	9°	7.8	25.6	Yes	26
30 / OFF								26
31 / OFF								26

³ If Cl₂ at entry point < 0.2 mg/l, OR-CT not met, notify DWP by end of next business day.