

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- B Month/Year: December 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	.091	OFF	.095
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	.069	OFF	OFF	.077
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	.099	OFF	OFF	.099
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		Notes: Plant not in use	
12-10-21 — 12-31-21		PRINTED NAME: BARRY ARNOLD	DATE: 1-7-22
		SIGNATURE: <i>Barry Arnold</i>	CERT #: 3636
		PHONE #: (541) 547-3315	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-B Month/Year: December 2021 Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/4:00	1.0	105	105	12°	7.6	20.9	YES	23
2/0#								23
3/12:00	.9	105	95	12°	7.7	21.4	YES	23
4/0#								23
5/0#								23
6/0#								23
7/0#								23
8/0#								23
9/12:00	1.0	105	105	12°	7.6	20.9	YES	24
10/								24
11/								24
12/								24
13/								24
14/								24
15/								24
16/								20
17/								20
18/								20
19/								20
20/								20
21/								20
22/								20
23/								20
24/								22
25/								22
26/								22
27/								22
28/								22
29/								22
30/								22
31/								22

not in use

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.