

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP--WTP- B Month/Year: September 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	.038	OFF	OFF	.044
2	OFF	---	---	---	---	---	---
3	OFF	---	---	---	---	---	---
4	OFF	---	---	---	---	---	---
5	OFF	---	---	---	---	---	---
6	OFF	---	---	---	---	---	---
7	OFF	---	---	---	---	---	---
8	OFF	OFF	OFF	.034	OFF	OFF	.043
9	OFF	---	---	---	---	---	---
10	OFF	---	---	---	---	---	---
11	OFF	---	---	---	---	---	---
12	OFF	---	---	---	---	---	---
13	OFF	---	---	---	---	---	---
14	OFF	OFF	OFF	.031	OFF	OFF	.040
15	OFF	---	---	---	---	---	---
16	OFF	---	---	---	---	---	---
17	OFF	---	---	---	---	---	---
18	OFF	---	---	---	---	---	---
19	OFF	---	---	---	---	---	---
20	OFF	---	---	---	---	---	---
21	OFF	OFF	OFF	.034	OFF	OFF	---
22	OFF	---	---	---	---	---	---
23	OFF	---	---	---	---	---	---
24	OFF	---	---	---	---	---	---
25	OFF	---	---	---	---	---	---
26	OFF	OFF	OFF	.031	OFF	OFF	.041
27	OFF	---	---	---	---	---	---
28	OFF	---	---	---	---	---	---
29	OFF	---	---	---	---	---	---
30	OFF	---	---	---	---	---	---
31	OFF	---	---	---	---	---	---

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No ²			
Notes:	PRINTED NAME: <i>Rick McClung</i>		
	SIGNATURE: <i>R. McClung</i>	DATE: 10/7/22	
	PHONE #: (541) 1547-3315	CERT #: 2725	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-B Month/Year: September 2022 Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/2:00	1.0	105	105	16°	7.6	15.9	Yes	18
2/ off								18
3/ off								18
4/ off								18
5/ off								18
6/ off								18
7/ off								18
8/2:45	1.1	105	116	16	7.5	15.5	Yes	18
9/ off								18
10/ off								19
11/ off								19
12/ off								19
13/ off								19
14/2:35	1.2	105	126	16	7.5	15.7	Yes	19
15/ off								19
16/ off								19
17/ off								19
18/ off								19
19/ off								19
20/ off								19
21/2:00	1.2	105	126	16	7.4	15.1	Yes	19
22/ off								19
23/ off								19
24/ off								18
25/ off								18
26/2:30	1.1	105	116	16	7.4	14.9	Yes	18
27/ off								18
28/ off								18
29/ off								18
30/ off								18
31/ off								18

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf
 PAGE 2 of 2