

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- 6 Month/Year: November 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
2	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
3	OFF	OFF	OFF	.067	OFF	OFF	.088
4	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
5	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
6	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
7	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
8	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
9	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
10	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
11	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
12	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
13	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
14	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
15	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
16	OFF	OFF	OFF	.085	OFF	OFF	.093
17	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
18	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
19	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
20	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
21	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
22	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
23	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
24	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
25	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
26	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
27	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
28	OFF	OFF	OFF	.074	OFF	OFF	.087
29	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
30	OFF	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~
31	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~	~~~~~

<p>Conventional or Direct Filtration</p> <p>95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No</p> <p>All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No</p> <p>All turbidity readings < IFE² triggers? <input checked="" type="checkbox"/> Yes / No²</p> <p>Notes:</p>	<p style="text-align: center;">Monthly Summary (Answer Yes or No)</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No</td> <td style="width: 50%;">All Cl₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No</td> </tr> </table> <p>PRINTED NAME: <u>Rick McClary</u></p> <p>SIGNATURE: <u>R. McClary</u> DATE: <u>12/2/22</u></p> <p>PHONE #: <u>(541) 547-3315</u> CERT #: <u>2725</u></p>	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No		

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. B Month/Year:

November 2022

Required Log Inactivation: .5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C.X.T	[°C]		Use tables	Yes / No	[GPM]
1 / OFF								15
2 / OFF								15
3 / 10:30	1.1	105	126	11	7.6	22.5	Yes	15
4 / OFF								15
5 / OFF								15
6 / OFF								15
7 / OFF								18
8 / OFF								18
9 / OFF								18
10 / OFF								18
11 / OFF								18
12 / OFF								18
13 / OFF								18
14 / OFF								18
15 / OFF								18
16 / 11:45	1.2	105	126	10	7.6	24.4	Yes	18
17 / OFF								18
18 / OFF								18
19 / OFF								18
20 / OFF								18
21 / OFF								20
22 / OFF								20
23 / OFF								20
24 / OFF								20
25 / OFF								20
26 / OFF								20
27 / OFF								20
28 / 11:00	1.2	105	126	10	7.5	23.5	Yes	20
29 / OFF								20
30 / OFF								20
31 /								20

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.