

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- 6 Month/Year: December 2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	---	---	---	---	---	
2	OFF	---	---	---	---	---	
3	OFF	---	---	---	---	---	
4	OFF	---	---	---	---	---	
5	OFF	---	---	---	---	---	
6	OFF	---	---	---	---	---	
7	OFF	---	---	---	---	---	
8	OFF	---	---	---	---	---	
9	OFF	---	---	---	---	---	
10	OFF	---	---	---	---	---	
11	OFF	---	---	---	---	---	
12	OFF	---	---	---	---	---	
13	OFF	---	---	---	---	---	
14	OFF	OFF	OFF	.053	OFF	OFF	.073
15	OFF	---	---	---	---	---	
16	OFF	---	---	---	---	---	
17	OFF	---	---	---	---	---	
18	OFF	---	---	---	---	---	
19	OFF	---	---	---	---	---	
20	OFF	---	---	---	---	---	
21	OFF	---	---	---	---	---	
22	OFF	OFF	OFF	.058	OFF	OFF	.081
23	OFF	---	---	---	---	---	
24	OFF	---	---	---	---	---	
25	OFF	---	---	---	---	---	
26	OFF	---	---	---	---	---	
27	OFF	OFF	OFF	.056	OFF	OFF	.078
28	OFF	---	---	---	---	---	
29	OFF	---	---	---	---	---	
30	OFF	---	---	---	---	---	
31	OFF	---	---	---	---	---	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Notes:	
Notes:		PRINTED NAME: Rick McClung	DATE: 1/10/23
Notes:		SIGNATURE: R. McClung	CERT #: 2725
Notes:		PHONE #: (541) 547-3315	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. 8 Month/Year: December 2022 Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / off	—	—	—	—	—	—	—	23
2 / off	—	—	—	—	—	—	—	23
3 / off	—	—	—	—	—	—	—	23
4 / off	—	—	—	—	—	—	—	23
5 / off	—	—	—	—	—	—	—	23
6 / off	—	—	—	—	—	—	—	23
7 / off	—	—	—	—	—	—	—	23
8 / off	—	—	—	—	—	—	—	23
9 / off	—	—	—	—	—	—	—	23
10 / off	—	—	—	—	—	—	—	23
11 / off	—	—	—	—	—	—	—	21
12 / off	—	—	—	—	—	—	—	21
13 / off	—	—	—	—	—	—	—	21
14 / 1:30	1.1	105	116	9°	7.6	25.7	—	21
15 / off	—	—	—	—	—	—	—	21
16 / off	—	—	—	—	—	—	—	21
17 / off	—	—	—	—	—	—	—	21
18 / off	—	—	—	—	—	—	—	25
19 / off	—	—	—	—	—	—	—	25
20 / off	—	—	—	—	—	—	—	25
21 / off	—	—	—	—	—	—	—	25
22 / 1:15	1.1	105	116	9°	7.4	24.0	—	25
23 / off	—	—	—	—	—	—	—	25
24 / off	—	—	—	—	—	—	—	25
25 / off	—	—	—	—	—	—	—	25
26 / off	—	—	—	—	—	—	—	20
27 / 1:00	1.2	105	126	9°	7.5	25.1	—	20
28 / off	—	—	—	—	—	—	—	20
29 / off	—	—	—	—	—	—	—	20
30 / off	—	—	—	—	—	—	—	20
31 / off	—	—	—	—	—	—	—	20

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.