

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST **ID #:** OR4100925 **WTP:-WTP- B** **Month/Year:** April 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							
2							
3				.079	OFF	OFF	.083
4							
5							
6							
7							
8	OFF	OFF	OFF	.082	.071	OFF	.087
9							
10	OFF	OFF	OFF	OFF	.078	OFF	.097
11							
12							
13							
14							
15							
16							
17							
18	OFF	OFF	OFF	.097	.068	OFF	.097
19							
20							
21							
22	OFF	OFF	OFF	.067	.080	OFF	.083
23							
24							
25	OFF	OFF	OFF	.063	.077	OFF	.079
26							
27							
28							
29							
30							
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: Rick McClung	
		SIGNATURE: R. McClung	DATE: 5/9/25
		PHONE #: ()	CERT #: 2527

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-B Month/Year: April 2025

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /								14
2 /								14
3 / 12:00	1.05	105	110	12	7.6	21.0	Yes	14
4 /								14
5 /								14
6 /								14
7 /								14
8 / 1:00	1.1	105	116	12	7.7	21.9	Yes	15
9 /								15
10 / 2:00	1.14	105	116	12	7.8	22.6	Yes	15
11 /								15
12 /								15
13 /								15
14 /								15
15 /								18
16 /								18
17 /								18
18 / 1:00	1.01	105	106	12.5	7.8	20.9	Yes	18
19 /								18
20 /								18
21 /								18
22 / 12:00	1.2	105	126	12	7.6	21.3	Yes	21
23 /								21
24 /								21
25 / 10:00	1.1	105	116	12	7.7	22.6	Yes	21
26 /								21
27 /								21
28 /								21
29 /								19
30 /								19
31 /								

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf