

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP- B Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF			.083	.075	—	.087
2							
3							
4							
5							
6							
7							
8							
9	OFF				.078	—	.090
10							
11	—						
12							
13				.068	.066	—	.103
14							
15				.099	—		.123
16	OFF	—	.078	.074	—	—	.085
17							
18							
19							
20							
21					.090	.088	.095
22							
23							
24							
25	OFF						
26							
27							
28				.042	.033	—	.082
29							
30							
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: <u>Rick McClung</u>	
		SIGNATURE: <u>R. McClung</u>	DATE: <u>6/1/25</u>
		PHONE #: ()	CERT #: <u>2725</u>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-B Month/Year:

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/2:40	1.2	105	126	13	7.7	20.6	Yes	20
2/								20
3/								20
4/								20
5/								20
6/								20
7/								18
8/								18
9/3:00	1.0	105	105	13	7.6	19.4	Yes	18
10/								18
11/								18
12/								18
13/11:00	1.2	105	126	14	7.6	18.6	Yes	14
14/								14
15/1:00	1.2	105	126	14	7.9	20.8	Yes	14
16/9:50	1.2	105	126	14	7.8	20.0	Yes	14
17/								14
18/								12
19/								19
20/								19
21/4:00 PM	1.1	105	116	14	7.8	19.8	Yes	19
22/								19
23/								19
24/								19
25/								20
26/								20
27/								20
28/11:00	1.1	105	116	14	7.7	19.1	Yes	20
29/								20
30/								20
31/								20

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf