

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: **Lincoln**
Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST **ID #:** OR4100925 **WTP:-WTP:** 3 **Month/Year:** July 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF						
2							
3				.036	.026		.040
4	OFF						
5							
6							
7							
8							
9				.032			.042
10							
11				.031			.074
12	OFF						
13							
14							
15							
16							
17			.040	.034	.034	.031	.041
18	OFF			.036			.104
19							
20							
21							
22							
23	OFF		.040	.035			.050
24							
25							
26							
27							
28							
29	OFF			.033	.030		.078
30							
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes: 		PRINTED NAME: Rick McElroy	
		SIGNATURE: R. McElroy	
		DATE: 7/31/25	
		PHONE #: (541) 547-3315	
		CERT #: 2725	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
 IFE = Indiv. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP-5 Month/Year: July 2025

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / off								19
2 /								19
3 / 12:00	1.3	105	137	16	7.6	16.5	Yes	19
4 /								19
5 /								19
6 /								19
7 /								17
8 /								17
9 / 3:00	1.2	105	126	16	7.6	16.3	Yes	17
10 /								17
11 / 12:00	1.4	105	147	16	7.5	16.1	Yes	17
12 /								17
13 /								17
14 /								18
15 /								18
16 /								18
17 / 11:00	1.2	105	126	17	7.5	14.7	Yes	18
18 / 1:00	1.5	105	158	16	7.6	16.8	Yes	18
19 /								21
20 /								21
21 /								21
22 /								21
23 / 3:00	1.4	105	147	16	7.3	14.9	Yes	21
24 /								21
25 /								21
26 /								21
27 /								23
28 /								23
29 / 12:00	1.4	105	147	17	7.3	13.9	Yes	23
30 /								23
31 /								23

³ If Cl₂ at entry point < 0.2 mg/L, OR CT, not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf