

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln
 Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP B Month/Year: August 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2				.037			.060
3							
4							
5							
6				.090	.056		.110
7							
8				.070	.063		.090
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21				.040	.078		.087
22							
23							
24							
25							
26							
27							
28				.035	.040		.060
29							
30							
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All the 4-hour turbidity readings ≤ 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE ² triggers? ☒ Yes / ☐ No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) ☒ Yes / ☐ No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	
Notes:		PRINTED NAME: Rick McClung	
		SIGNATURE: R. McClung	DATE: 9/3/25
		PHONE #: (541) 819-2274	CERT #: 2725

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
 IFE = Indiv. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP 5 Month/Year: August 2005 Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1 / 1:00	1.4	105	147	17	7.3	13.9	Yes	22
2 /								22
3 /								22
4 /								22
5 / 2:00	1.5	105	158	17	7.4	14.6	Yes	22
6 /								22
7 / 1:00	1.4	105	147	17	7.5	15.0	Yes	20
8 /								20
9 /								20
10 /								18
11 /								18
12 /								18
13 /								18
14 /								18
15 /								18
16 /								18
17 /								16
18 /								16
19 /								16
20 / 12:00	1.1	105	116	18	7.3	12.6	Yes	16
21 /								16
22 /								16
23 /								16
24 /								14
25 /								14
26 /								14
27 /								14
28 / 12:00	1.4	105	147	18	7.4	13.5	Yes	14
29 /								14
30 /								14
31 /								14

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf