

**OHA - Drinking Water Program – Turbidity Monitoring Report Form** County: Lincoln  
**Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP B Month/Year: Dec. 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	—	—	.070	.062	.064	.098
2	OFF	—	—	.040	OFF	—	.567
3	—	—	—	—	—	—	—
4	—	—	—	—	—	—	—
5	—	—	—	—	—	—	—
6	—	—	—	—	—	—	—
7	—	—	—	—	—	—	—
8	OFF	—	—	.080	—	—	.096
9	—	—	—	—	—	—	—
10	—	—	—	—	—	—	—
11	OFF	—	—	.041	—	—	.061
12	—	—	—	.070	—	—	.081
13	—	—	—	—	—	—	—
14	—	—	—	—	—	—	—
15	—	—	—	—	—	—	—
16	OFF	—	—	.115	.126	—	.126
17	—	—	—	—	—	—	—
18	—	—	—	—	—	—	—
19	—	—	—	—	—	—	—
20	—	—	—	—	—	—	—
21	—	—	—	—	—	—	—
22	—	—	—	—	—	—	—
23	OFF	—	—	.075	.080	—	.087
24	—	—	—	—	—	—	—
25	—	—	—	—	—	—	—
26	—	—	—	—	—	—	—
27	—	—	—	—	—	—	—
28	—	—	—	—	—	—	—
29	OFF	—	.045	.084	.110	—	.110
30	—	—	—	.120	—	—	.120
31	—	—	—	.110	—	—	.112

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see-back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No <sup>2</sup>			
Notes: Rick McIlhenny DRC cert # 2725		PRINTED NAME: Gabe Greenwood	DATE: 1-7-26
		SIGNATURE:	CERT #: 2725
		PHONE #: (808) 212-7866	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indiv. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP B Month/Year: December 2025 Required Log Inactivation: 5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/12:00	1.2	105	126	13	7.8	21.4	Yes	19
2/1:00	1.4	105	147	13	7.9	22.7	Yes	19
3/								19
4/								19
5/								19
6/								19
7/								19
8/1:00	1.4	105	147	12	7.8	23.4	Yes	18
9/								18
10/								18
11/10:30	1.3	105	137	12	7.7	22.4	Yes	18
12/2:00	1.5	105	158	12	7.8	23.7	Yes	18
13/								18
14/								18
15/								19
16/2:00	1.3	105	137	12	7.7	22.4	Yes	19
17/								19
18/								19
19/								22
20/								22
21/								22
22/								22
23/12:00	1.3	105	137	12	7.6	21.6	Yes	22
24/								22
25/								25
26/								25
27/								25
28/								25
29/10:00	1.5	105	158	12	7.6	22.1	Yes	25
30/9:00	1.6	105	168	11	7.6	23.9	Yes	25
31/11:00	1.4	105	147	11	7.6	23.3	Yes	25

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT, not met, notify DWP by end of next business day.