

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Lincoln
Conventional or Direct Filtration**

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP B Month/Year: February 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2				.045			.096
3							
4							
5							
6				.052	.050		.085
7							
8							
9				.040			.090
10							
11							
12							
13							
14							
15							
16							
17							
18					.099		.112
19							
20					.087		.127
21							
22							
23							
24							
25				.101			.107
26							
27							
28							
29							
30							
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday?	All Cl ₂ residuals at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	Yes / No	(see back)	Yes / No
All turbidity readings < IFE ² triggers?	Yes / No ²	Yes / No	
Notes:		PRINTED NAME: Rick McClung	DATE: 2/25/26
		SIGNATURE: R. McClung	CERT #: 2225
		PHONE #: (541) 819-2279	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP. B. Month/Year: February 2026

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C.X.T	Temp [°C]	pH	Required CT Use tables	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
1 /								20
2 / 12:00	1.3	105	137	10	7.7	25.5	Yes	20
3 /								20
4 /								20
5 /								20
6 / 12:00	1.0	105	105	10	7.5	23.0	Yes	20
7 /								20
8 /								20
9 / 12:00	1.0	105	105	10	7.7	24.7	Yes	22
10 /								22
11 /								22
12 /								22
13 /								22
14 /								22
15 /								22
16 /								19
17 /								19
18 / 3:00	1.1	105	116	10	7.5	23.2	Yes	19
19 /								19
20 / 3:30	1.6	105	165	10	7.6	23.8	Yes	19
21 /								19
22 /								19
23 /								21
24 /								21
25 / 12:00	1.0	105	105	10	7.5	23.0	Yes	21
26 /								21
27 /								21
28 /								21
29 /								21
30 /								
31 /								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.