

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: **Lincoln**
Conventional or Direct Filtration

System Name: SW LINCOLN CO WATER DIST ID #: OR4100925 WTP:-WTP 3 Month/Year: March 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.12						
2							
3							
4							
5							
6							
7							
8							
9							
10	OFF	OFF	.098	.060	.046		.112
11	OFF	OFF	OFF	.075			.100
12							
13							
14							
15							
16							
17							
18							
19							
20				.095			.117
21							
22							
23							
24							
25							
26	OFF				.045		.090
27							
28							
29							
30	OFF			.060			.097
31							

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u> Notes:	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <u>Yes No</u>	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <u>Yes / No</u>
PRINTED NAME: <u>Rick McClincy</u>	SIGNATURE: <u>R. McClincy</u>	DATE: <u>3/31/26</u>
PHONE #: <u>(541) 819-2299</u>	CERT #: <u>2725</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

SW LINCOLN CO WATER DIST ID #: OR4100925 WTP: WTP B Month/Year: March 2026

Required Log Inactivation: 5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1 /								13
2 /								13
3 /								13
4 /								13
5 /								13
6 /								13
7 /								13
8 /								14
9 /								14
10 / 12:00	.90	105	95	10	7.6	23.5	Yes	14
11 / 2:00	1.1	105	116	10	7.6	24.1	Yes	14
12 /								14
13 /								14
14 /								14
15 /								12
16 /								12
17 /								12
18 /								12
19 /								12
20 / 7:00	1.1	105	116	11	7.5	21.8	Yes	12
21 /								12
22 /								14
23 /								14
24 /								14
25 /								14
26 / 4:00	1.0	105	105	11	7.6	22.3	Yes	14
27 / ✓								14
28 /								14
29 /								13
30 / 12:00	1.1	105	116	12	7.6	21.1	Yes	13
31 /								13

² If Cl₂ at entry point < 0.2 mg/L, OR CT, not met, notify DWP by end of next business day.