

Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: City of Waldport

ID #: 41 00926

Month/Year: 10/22

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	OFF	OFF	.05	.05	.05	.05	0.05	~ 350
2	.05	.05	.05	.06	.05	.05	0.06	~ 350
3	.05	.05	.05	.06	OFF	OFF	0.06	~ 350
4	OFF	OFF	.09	.06	.05	.05	0.09	~ 350
5	.05	.05	.05	.06	.05	OFF	0.06	~ 350
6	OFF	OFF	OFF	OFF	OFF	OFF	0	~ 350
7	OFF	OFF	.07	.05	.05	.05	0.07	~ 350
8	.05	.05	.05	.05	.05	.05	0.05	~ 350
9	.05	.06	.05	.05	.05	.05	0.06	~ 350
10	.05	.05	.06	.05	.05	.05	0.06	~ 350
11	.05	.05	OFF	OFF	OFF	OFF	0.05	~ 350
12	OFF	.05	.05	.05	.05	.05	0.05	~ 350
13	.05	.05	.05	.05	.07	OFF	0.07	~ 350
14	OFF	OFF	.07	.05	.05	.05	0.07	~ 350
15	.05	.05	OFF	OFF	OFF	OFF	0.05	~ 350
16	OFF	OFF	OFF	.05	.06	.05	0.06	~ 350
17	.05	.05	.05	.05	.05	.05	0.05	~ 350
18	.05	.05	.05	.05	.05	OFF	0.05	~ 350
19	OFF	OFF	.07	.05	.05	.05	0.07	~ 350
20	OFF	OFF	OFF	.05	.05	.05	0.05	~ 350
21	.05	.05	.05	.05	.05	OFF	0.05	~ 350
22	OFF	OFF	OFF	OFF	OFF	OFF	0	~ 350
23	OFF	OFF	.06	.05	.05	.05	0.06	~ 350
24	.05	.05	.05	.05	.06	.05	0.06	~ 350
25	.05	.05	.05	.05	.05	OFF	0.05	~ 350
26	OFF	OFF	.06	.06	.05	.05	0.06	~ 350
27	.05	.05	OFF	.05	.05	OFF	0.05	~ 350
28	OFF	OFF	OFF	OFF	OFF	OFF	0	~ 350
29	OFF	OFF	.05	.05	.06	.05	0.06	~ 350
30	.06	.05	.05	.05	.05	.05	0.06	~ 350
31	OFF	OFF	OFF	OFF	OFF	OFF	0	~ 350

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)		
95% of turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	Cl ₂ residual measured in of distribution sample
All turbidity readings < 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No ¹			
- OR -		PRINTED NAME: <u>Lyle T. Arrant</u>		
Slow Sand/Cartridge/Membrane/DE Filtration		SIGNATURE: <u>Lyle T. Arrant</u>	DATE: <u>11/03/22</u>	
95% of turbidity readings ≤ 1 NTU?	Yes / No	PHONE #: <u>(541) 563-2929</u>	CERT #: <u>5292</u>	
All turbidity readings < 5 NTU?	Yes / No			

¹ IFE = Individual Filter Effluent

Amended report
 decimal points was not correct on the previous report