

Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

 System Name: City of Waldport

 ID #: 4100926

 Month/Year: 2/24

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	off	off	.03	.03	.03	off	.03	≤ 350
2	off	off	off	.03	.04	.03	.04	≤ 350
3	off	off	.03	.04	off	.03	.03	≤ 350
4	.03	.03	.03	.03	.03	off	.03	≤ 350
5	off	off	.03	.03	.03	.03	.03	≤ 350
6	.03	.03	.03	.03	.03	.03	.03	≤ 350
7	.04	off	.03	.03	.03	.04	.04	≤ 350
8	off	off	.03	.03	.03	off	.03	≤ 350
9	off	off	.03	off	.03	.03	.03	≤ 350
10	.03	.03	.03	.04	.03	off	.04	≤ 350
11	off	off	.03	off	off	off	.03	≤ 350
12	.03	.03	.03	.04	.03	.03	.04	≤ 350
13	.03	off	.04	.03	.03	.03	.04	≤ 350
14	.03	.03	off	off	off	off	.03	≤ 350
15	off	off	.04	.03	.04	off	.04	≤ 350
16	off	off	.03	.03	.03	.03	.03	≤ 350
17	.03	off	.03	.03	.03	.03	.03	≤ 350
18	.03	.03	.04	.03	.03	.03	.03	≤ 350
19	.03	off	off	off	off	off	.03	≤ 350
20	off	off	.04	.03	.03	.03	.04	≤ 350
21	.03	.03	.04	.03	.03	.03	.04	≤ 350
22	.03	.03	.03	.03	.03	off	.03	≤ 350
23	off	off	.04	.04	.03	.03	.04	≤ 350
24	off	off	.03	.03	.03	.03	.03	≤ 350
25	.03	.04	.03	.03	.03	off	.04	≤ 350
26	off	off	.03	.03	.03	.03	.03	≤ 350
27	.03	.03	.04	.03	.03	.03	.04	≤ 350
28	.04	.03	off	.04	.04	.03	.04	≤ 350
29	off	off	off	off	off	off	.04	≤ 350
30								
31								

Conventional or Direct Filtration
Monthly Summary (Answer Yes or No)

 95% of turbidity readings ≤ 0.3 NTU? Yes / No
 All turbidity readings < 1 NTU? Yes / No
 All turbidity readings < IFE triggers? Yes / No


 CT's met everyday? (see back)
 Yes / No

 All Cl₂ residual at entry point ≥ 0.2 mg/l?
 Yes / No

 Cl₂ residual measured in 95% of distribution samples?
 Yes / No

- OR -

PRINTED NAME:


Slow Sand/Cartridge/Membrane/DE Filtration

SIGNATURE:

 DATE: 3-7-24

 95% of turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < 5 NTU? Yes / No

 PHONE #: (541) 563-2929

 CERT #: 5298

IFE = Individual Filter Effluent

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / No
11/200	1.0	360	360	15	7.6	15	Yes
210920	0.9	360	324	13	7.5	15	Yes
310940	1.0	360	360	13	7.6	15	Yes
410900	1.0	360	360	13	7.4	15	Yes
511800	1.0	360	360	14	7.5	15	Yes
611700	1.0	360	360	13	7.5	15	Yes
710845	0.9	360	324	14	7.5	15	Yes
810800	1.0	360	360	13	7.5	15	Yes
910840	0.8	360	288	12	7.3	22	Yes
1010900	0.9	360	324	12	7.4	22	Yes
1110845	0.9	360	324	15	7.4	15	Yes
1211800	1.0	360	360	13	7.5	15	Yes
1311630	1.0	360	360	13	7.5	15	Yes
1410900	1.0	360	360	14	7.5	15	Yes
1510900	1.0	360	360	13	7.5	15	Yes
1610900	1.0	360	360	12	7.5	22	Yes
171900	1.0	360	360	12	7.5	22	Yes
180830	0.9	360	324	15	7.5	15	Yes
191100	1.0	360	360	11	7.4	22	Yes
2011600	1.0	360	360	12	7.5	22	Yes
2111530	1.0	360	360	14	7.4	15	Yes
2211430	1.0	360	360	13	7.5	15	Yes
230900	1.0	360	360	15	7.4	15	Yes
2411750	0.9	360	324	16	7.5	15	Yes
2510900	1.1	360	396	15	7.4	15	Yes
2611800	1.0	360	360	13	7.5	15	Yes
2711600	1.0	360	360	13	7.5	15	Yes
2811700	1.0	360	360	14	7.5	15	Yes
291100	1.1	360	396	12	7.5	22	Yes
301							
311							