

Oregon DHS - Drinking Water Program - Turbidity Monitoring Report Form

System Name: City of Waldport ID #: 41 00926 Month/Year: March 2025

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.02	.03	.02	.02	.02	.02	.03	≤ 350
2	off	off	off	off	off	off	0	≤ 350
3	.03	.02	.02	.02	.02	.02	.02	≤ 350
4	.02	.02	.02	.02	.02	.02	.02	≤ 350
5	.02	.02	.02	.03	.02	.02	.03	≤ 350
6	.02	.03	.02	.02	.02	.02	.03	≤ 350
7	.02	.02	.02	.02	.02	.02	.02	≤ 350
8	.02	.02	.02	.02	.02	.02	.02	≤ 350
9	.02	.02	.02	.02	.02	.03	.03	≤ 350
10	.02	.02	.02	.03	.02	.03	.03	≤ 350
11	.02	.02	.02	.02	.02	.02	.02	≤ 350
12	.02	.02	.02	.02	.02	.02	.02	≤ 350
13	.02	.02	.02	.02	.02	.02	.02	≤ 350
14	.03	.03	.02	.02	.02	.02	.03	≤ 350
15	off	off	off	off	off	off	0	≤ 350
16	.02	.02	.02	.03	.02	.02	.03	≤ 350
17	.02	.02	.02	.02	.02	.02	.02	≤ 350
18	.02	.02	.02	.02	.02	.02	.02	≤ 350
19	.02	.02	.02	.02	.02	.02	.02	≤ 350
20	.02	.02	.03	.02	.02	.02	.03	≤ 350
21	off	off	off	off	off	off	0	≤ 350
22	.02	.02	.02	.03	.02	.02	.03	≤ 350
23	.02	.02	.02	.02	.02	.02	.02	≤ 350
24	.02	.02	.02	.02	.02	.03	.03	≤ 350
25	.02	.02	.02	.02	.02	.02	.02	≤ 350
26	.02	.02	.02	.02	.02	.02	.02	≤ 350
27	.03	.02	.02	.02	.02	.02	.03	≤ 350
28	off	off	off	off	off	off	0	≤ 350
29	.02	.02	.02	.03	.02	.02	.03	≤ 350
30	.02	.02	.02	.02	.02	.03	.03	≤ 350
31	off	off	off	off	off	off	off	≤ 350

Conventional or Direct Filtration 95% of turbidity readings ≤ 0.3 NTU? ☒ Yes / ☐ No All turbidity readings < 1 NTU? ☒ Yes / ☐ No All turbidity readings < IFE triggers? ☒ Yes / ☐ No ¹		Monthly Summary (Answer Yes or No) <table style="width: 100%; border: none;"> <tr> <td style="width: 33%; border: none; padding: 2px;">CT's met everyday? (see back) ☒ Yes / ☐ No</td> <td style="width: 33%; border: none; padding: 2px;">All Cl₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No</td> <td style="width: 33%; border: none; padding: 2px;">Cl₂ residual measured in 95% of distribution samples? ☒ Yes / ☐ No</td> </tr> </table>			CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	Cl ₂ residual measured in 95% of distribution samples? ☒ Yes / ☐ No
CT's met everyday? (see back) ☒ Yes / ☐ No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? ☒ Yes / ☐ No	Cl ₂ residual measured in 95% of distribution samples? ☒ Yes / ☐ No					
- OR -		PRINTED NAME: <u>James Ledbetter</u>					
Slow Sand/Cartridge/Membrane/DE Filtration 95% of turbidity readings ≤ 1 NTU? ☐ Yes / ☐ No All turbidity readings < 5 NTU? ☐ Yes / ☐ No		SIGNATURE: <u>James Ledbetter</u>		DATE: <u>4-2-2025</u>			
		PHONE #: <u>(541) 563-2929</u>		CERT #:			

¹ IFE = Individual Filter Effluent

System Name:

City of Walpole

ID #: 4100926

Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	Yes / No
1/09:30	1.0	325	325	14	7.5	15	yes
2/09:30	1.0	325	325	14	7.4	15	yes
3/09:30	1.0	325	325	13	7.5	15	yes
4/08:20	1.0	325	325	14	7.2	15	yes
5/08:15	1.0	325	325	13	7.4	15	yes
6/08:00	1.0	325	325	13	7.6	15	yes
7/08:30	1.1	325	358	12	7.5	22	yes
8/07:40	1.0	325	325	12	7.5	22	yes
9/08:30	1.0	325	325	13	7.5	15	yes
10/08:30	1.0	325	325	15	7.4	15	yes
11/08:30	1.0	325	325	13	7.5	15	yes
12/12:30	1.0	325	325	13	7.5	15	yes
13/10:30	1.0	325	325	13	7.4	15	yes
14/11:00	1.0	325	325	11	7.5	22	yes
15/08:30	1.0	325	325	11	7.5	22	yes
16/18:00	1.1	325	358	14	7.4	15	yes
17/08:15	1.1	325	358	14	7.4	15	yes
18/09:00	1.0	325	325	14	7.4	15	yes
19/08:30	1.0	325	325	15	7.4	15	yes
20/08:00	1.0	325	325	15	7.5	15	yes
21/08:00	1.1	325	358	16	7.4	15	yes
22/10:00	1.0	325	325	14	7.4	15	yes
23/08:30	0.9	325	293	15	7.4	15	yes
24/08:30	1.0	325	325	14	7.3	15	yes
25/11:00	1.0	325	325	16	7.4	15	yes
26/08:30	1.0	325	325	16	7.4	15	yes
27/08:30	1.0	325	325	15	7.4	15	yes
28/09:00	1.0	325	325	14	7.4	15	yes
29/09:00	1.0	325	325	14	7.4	15	yes
30/09:00	0.9	325	293	13	7.4	15	yes
31/09:00	0.9	325	293	14	7.4	15	yes