

System Name:

City of Waldport

ID #: 4100926

Month/Year: May 20

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.02	.02	.03	.02	.02	.02	.03	≤ 350
2	.03	.03	.02	.02	.02	.02	.03	≤ 350
3	off	—	—	—	—	—	—	≤ 350
4	off	—	—	—	—	—	—	≤ 350
5	off	—	—	—	—	—	—	≤ 350
6	.02	.02	.02	.02	.02	.02	.02	≤ 350
7	.02	.02	.02	.02	.02	.02	.02	≤ 350
8	.02	.03	.03	.03	.03	.02	.03	≤ 350
9	.03	.02	.02	.02	.02	.02	.03	≤ 350
10	.02	.02	.02	.02	.02	.02	.02	≤ 350
11	.02	.02	.02	.02	.02	.02	.02	≤ 350
12	.02	.03	.03	.02	.02	.02	.03	≤ 350
13	.03	.02	.02	.02	.02	.02	.03	≤ 350
14	.02	.02	.02	.02	.02	.02	.02	≤ 350
15	.02	.02	.02	.02	.02	.02	.02	≤ 350
16	.02	.02	.02	.02	.02	.02	.02	≤ 350
17	off	—	—	—	—	—	—	≤ 350
18	off	—	—	—	—	—	—	≤ 350
19	off	—	—	—	—	—	—	≤ 350
20	.02	.02	.02	.02	.02	.02	.02	≤ 350
21	.03	.02	.02	.02	.02	.02	.02	≤ 350
22	.02	.03	.03	.02	.02	.02	.03	≤ 350
23	.02	.02	.02	.02	.02	.02	.02	≤ 350
24	.02	.02	.02	.03	.02	.02	.03	≤ 350
25	off	—	—	—	—	—	—	≤ 350
26	off	—	—	—	—	—	—	≤ 350
27	.02	.02	.02	.02	.02	.02	.02	≤ 350
28	.02	.02	.02	.02	.02	.03	.03	≤ 350
29	.03	.03	.02	.02	.02	.02	.03	≤ 350
30	.02	.02	.02	.02	.02	.02	.02	≤ 350
31	.02	.02	.03	.03	.02	.02	.03	≤ 350

Conventional or Direct Filtration

95% of turbidity readings ≤ 0.3 NTU?

Yes / No

All turbidity readings < 1 NTU?

Yes / No

All turbidity readings < IFE triggers?

Yes / No¹

Monthly Summary (Answer Yes or No)

CT's met everyday?

(see back)

Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?

Yes / No

Cl₂ residual measured in

of distribution samples

Yes / No

- OR -

PRINTED NAME: James Ledbetter

Slow Sand/Cartridge/Membrane/DE Filtration

SIGNATURE: James Ledbetter

DATE: 6-2-20

95% of turbidity readings ≤ 1 NTU?

Yes / No

All turbidity readings < 5 NTU?

Yes / No

PHONE #: (541) 563-2325

CERT #: 0879

¹ IFE = Individual Filter Effluent

System Name:

City of Walldport

ID #: 41 00926

Month/Year: MAY 20

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes
1/08:15	1.1	325	358	16	7.4	15	ye
2/10:00	1.1	325	358	18	7.4	22	ye
3/08:15	0.9	325	293	17	7.4	15	ye
4/08:15	1.0	325	325	16	7.4	15	ye
5/08:00	1.0	325	325	17	7.5	15	ye
6/08:15	1.1	325	358	19	7.4	22	ye
7/08:30	1.0	325	325	18	7.4	22	ye
8/08:00	1.0	325	325	15	7.5	15	ye
9/08:30	1.0	325	325	15	7.6	15	ye
10/08:30	1.0	325	325	14	7.4	15	ye
11/08:25	1.0	325	325	16	7.4	15	ye
12/08:30	1.0	325	325	15	7.5	15	ye
13/06:00	1.1	325	358	19	7.4	22	ye
14/06:30	1.0	325	325	17	7.4	15	ye
15/06:30	1.0	325	325	18	7.5	22	ye
16/06:30	0.9	325	293	18	7.5	22	ye
17/08:30	1.1	325	358	16	7.4	15	ye
18/08:05	1.0	325	325	17	7.3	15	ye
19/09:30	1.0	325	325	18	7.4	22	ye
20/08:00	1.0	325	325	18	7.4	22	ye
21/08:30	1.1	325	358	16	7.3	15	ye
22/07:15	1.0	325	325	17	7.4	15	ye
23/07:00	1.0	325	325	17	7.3	15	ye
24/08:00	1.0	325	325	17	7.4	15	ye
25/09:00	0.9	325	293	22	7.4	22	ye
26/11:00	1.0	325	325	18	7.4	22	ye
27/08:30	1.0	325	325	17	7.4	22	ye
28/08:30	1.0	325	325	17	7.4	22	ye
29/08:15	1.0	325	325	17	7.4	22	ye
30/08:30	1.0	325	325	17	7.5	15	ye
31/08:55	1.0	325	325	16	7.3	15	ye