

System Name:

City of Waldport

ID #: 41

00926

Month/Year:

July 25

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.02	.02	.02	.02	.02	.03	.03	≤ 350
2	.03	.02	.02	.02	.02	.02	.03	≤ 350
3	.02	.02	.02	.02	.02	.02	.02	≤ 350
4	.02	.03	.03	.03	.02	.02	.03	≤ 350
5	.02	.02	.03	.02	.03	.03	.03	≤ 350
6	.02	.02	.02	.02	.02	.02	.02	≤ 350
7	.03	.02	.03	.02	.02	.02	.03	≤ 350
8	.03	.03	.02	.02	.02	.02	.03	≤ 350
9	.02	.02	.02	.03	.03	.03	.03	≤ 350
10	.02	.02	.02	.02	.02	.02	.02	≤ 350
11	.02	.02	.02	.02	.02	.02	.02	≤ 350
12	.02	.03	.03	.03	.03	.02	.03	≤ 350
13	.03	.02	.02	.03	.02	.02	.03	≤ 350
14	.02	.02	.02	.02	.02	.03	.03	≤ 350
15	.02	.02	.02	.02	.02	.02	.02	≤ 350
16	.02	.03	.02	.02	.02	.02	.03	≤ 350
17	.02	.02	.02	.02	.02	.02	.02	≤ 350
18	.03	.02	.02	.02	.02	.02	.03	≤ 350
19	.02	.02	.03	.02	.03	.02	.03	≤ 350
20	.02	.02	.02	.02	.02	.02	.02	≤ 350
21	.02	.03	.03	.03	.02	.03	.03	≤ 350
22	.02	.02	.02	.02	.02	.02	.02	≤ 350
23	.02	.02	.02	.02	.02	.02	.02	≤ 350
24	.03	.03	.03	.02	.02	.03	.03	≤ 350
25	.02	.02	.02	.02	.03	.03	.03	≤ 350
26	.02	.02	.02	.02	.02	.02	.02	≤ 350
27	.03	.02	.02	.02	.02	.02	.03	≤ 350
28	.02	.02	.02	.03	.02	.03	.03	≤ 350
29	.02	.02	.03	.02	.02	.02	.03	≤ 350
30	.02	.02	.02	.02	.02	.02	.02	≤ 350
31	.02	.02	.02	.02	.02	.02	.02	≤ 350

Conventional or Direct Filtration

95% of turbidity readings ≤ 0.3 NTU? Yes / No
 All turbidity readings < 1 NTU? Yes / No
 All turbidity readings < IFE triggers? Yes / No¹

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No
 Cl₂ residual measured in 95% of distribution samples? Yes / No

- OR -

PRINTED NAME: James Ledbetter

Slow Sand/Cartridge/Membrane/DE Filtration

SIGNATURE: James Ledbetter

DATE: 8-4-2025

95% of turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < 5 NTU? Yes / No

PHONE #: (541) 563-2325

CERT #: 08795

¹ IFE = Individual Filter Effluent

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / No
1 10900	1.1	325	358	16	7.5	15	yes
2 110900	1.0	325	325	17	7.6	15	yes
3 10800	1.1	325	358	18	7.4	22	yes
4 10830	1.0	325	325	17	7.3	15	yes
5 10830	0.9	325	292	16	7.6	15	yes
6 10815	0.8	325	260	20	7.5	22	yes
7 10630	1.1	325	358	16	7.4	15	yes
8 10700	1.0	325	325	17	7.4	15	yes
9 10700	1.0	325	325	18	7.5	22	yes
10 10900	1.0	325	325	17	7.6	15	yes
11 10900	1.1	325	358	18	7.6	22	yes
12 10900	1.0	325	325	18	7.5	22	yes
13 10800	0.9	325	292	18	7.6	22	yes
14 10815	0.8	325	260	20	7.5	22	yes
15 10830	0.9	325	292	18	7.6	22	yes
16 10845	1.0	325	325	17	7.6	15	yes
17 10730	1.0	325	325	20	7.6	22	yes
18 10830	1.0	325	325	20	7.6	22	yes
19 10900	1.0	325	325	19	7.6	22	yes
20 10845	0.9	325	292	19	7.7	22	yes
21 10845	1.1	325	358	17	7.6	15	yes
22 10930	1.0	325	325	18	7.6	22	yes
23 10830	1.0	325	325	18	7.6	22	yes
24 10730	1.1	325	358	19	7.6	22	yes
25 10830	1.0	325	325	18	7.6	22	yes
26 10830	1.0	325	325	18	7.6	22	yes
27 10830	1.0	325	325	18	7.6	22	yes
28 10800	1.1	325	358	17	7.6	15	yes
29 10800	1.0	325	325	18	7.6	22	yes
30 10800	1.0	325	325	18	7.6	22	yes
31 10830	1.0	325	325	19	7.6	22	yes