

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.02	.02	.02	.02	.02	.02	.02	≤ 350
2	.02	.02	.02	.02	.02	.02	.03	≤ 350
3	.03	.03	.02	.03	.03	.02	.03	≤ 350
4	.03	.02	.02	.02	.02	.03	.03	≤ 350
5	.02	.03	.03	.02	.02	.02	.03	≤ 350
6	.02	.02	.02	.02	.02	.02	.02	≤ 350
7	.02	.02	.02	.02	.02	.02	.02	≤ 350
8	.02	.03	.02	.02	.02	.02	.03	≤ 350
9	.03	.02	.02	.02	.02	.02	.03	≤ 350
10	.02	.02	.02	.02	.02	.02	.02	≤ 350
11	.02	.02	.02	.02	.02	.02	.02	≤ 350
12	.02	.02	.02	.02	.02	.03	.03	≤ 350
13	.03	.02	.02	.02	.02	.02	.03	≤ 350
14	.02	.02	.02	.02	.02	.02	.02	≤ 350
15	.02	.02	.03	.02	.02	.02	.03	≤ 350
16	.03	.03	.02	.02	.02	.02	.03	≤ 350
17	.02	.03	.03	.03	.02	.03	.03	≤ 350
18	.02	.02	.02	.02	.02	.02	.02	≤ 350
19	.02	.02	.02	.02	.02	.02	.02	≤ 350
20	.02	.02	.02	.02	.02	.02	.02	≤ 350
21	.03	.02	.02	.02	.03	.03	.03	≤ 350
22	.03	.02	.03	.03	.02	.02	.03	≤ 350
23	.02	.02	.02	.02	.02	.02	.02	≤ 350
24	.02	.02	.02	.02	.02	.02	.02	≤ 350
25	.02	.02	.02	.03	.03	.02	.03	≤ 350
26	.03	.03	.03	.02	.02	.03	.03	≤ 350
27	.02	.02	.02	.02	.02	.02	.02	≤ 350
28	.02	.02	.02	.02	.02	.02	.02	≤ 350
29	.03	.02	.03	.03	.03	.02	.03	≤ 350
30	.02	.02	.02	.02	.02	.02	.02	≤ 350
31	.02	.02	.02	.02	.02	.02	.02	≤ 350

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	Cl ₂ residual measured in 95% of distribution samples?
All turbidity readings < 1 NTU?	Yes / No	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE triggers?	Yes / No ¹			

- OR -

PRINTED NAME: James Ledbetter

Slow Sand/Cartridge/Membrane/DE Filtration

SIGNATURE: James LedbetterDATE: 11-7-25

95% of turbidity readings ≤ 1 NTU?

Yes / No

PHONE #: (541) 543-2325

CERT #: J-08795

All turbidity readings < 5 NTU?

Yes / No

¹ IFE = Individual Filter Effluent

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met
							Yes / No
	ppm or mg/L	minutes	CXT	°C		Use tables	
1/0830	1.0	325	325	21	7.4	22	yes
2/0800	1.0	325	325	20	7.5	22	yes
3/0800	1.0	325	325	19	7.4	22	yes
4/0830	1.0	325	325	20	7.5	22	yes
5/0830	0.8	325	260	17	7.4	15	yes
6/0900	0.9	325	292	14	7.4	15	yes
7/0930	0.9	325	292	16	7.4	15	yes
8/0700	0.9	325	292	17	7.3	15	yes
9/0800	0.9	325	292	16	7.4	15	yes
10/0730	0.9	325	292	16	7.5	15	yes
11/0830	0.9	325	292	17	7.5	15	yes
12/0900	0.8	325	260	18	7.5	22	yes
13/0900	0.9	325	292	19	7.4	22	yes
14/0830	0.9	325	292	14	7.5	15	yes
15/0830	0.9	325	292	16	7.6	15	yes
16/0830	0.8	325	260	14	7.5	15	yes
17/0730	0.8	325	260	16	7.5	15	yes
18/0700	0.7	325	228	15	7.3	15	yes
19/0930	0.9	325	292	14	7.5	15	yes
20/0900	0.9	325	292	15	7.5	15	yes
21/0840	0.8	325	260	15	7.3	15	yes
22/0900	0.8	325	260	15	7.4	15	yes
23/0900	0.8	325	260	16	7.5	15	yes
24/0900	0.7	325	228	17	7.3	15	yes
25/0830	0.8	325	260	15	7.4	15	yes
26/0900	0.9	325	292	15	7.4	15	yes
27/0900	0.8	325	260	16	7.4	15	yes
28/0830	0.9	325	292	15	7.5	15	yes
29/0700	0.9	325	292	15	7.5	15	yes
30/0700	0.8	325	260	14	7.5	15	yes
31/0730	0.9	325	292	15	7.5	15	yes