

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	OFF	—	—	—	—	—	OFF	≤ 350
2	.02	.02	.02	.03	.02	.02	.03	≤ 350
3	.02	.02	.02	.02	.02	.03	.03	≤ 350
4	.03	.03	.03	.02	.02	.02	.03	≤ 350
5	.02	.02	.02	.02	.02	.02	.02	≤ 350
6	.02	.02	.02	.02	.02	.02	.02	≤ 350
7	.02	.03	.03	.02	.02	.03	.03	≤ 350
8	.02	.02	.02	.02	.02	.02	.02	≤ 350
9	.02	.07	.02	.02	.02	.02	.02	≤ 350
10	.03	.02	.02	.03	.03	.02	.03	≤ 350
11	.03	.03	.02	.02	.02	.02	.03	≤ 350
12	.02	.02	.02	.02	.02	.02	.02	≤ 350
13	.02	.02	.03	.02	.03	.03	.03	≤ 350
14	.02	.02	.02	.02	.02	.02	.02	≤ 350
15	.02	.02	.02	.02	.03	.02	.03	≤ 350
16	OFF	—	—	—	—	—	OFF	≤ 350
17	.02	.02	.02	.02	.02	.02	.02	≤ 350
18	.03	.03	.03	.03	.03	.03	.03	≤ 350
19	.03	.02	.02	.03	.02	.02	.03	≤ 350
20	.02	.02	.02	.02	.02	.02	.02	≤ 350
21	.02	.02	.02	.03	.02	.03	.03	≤ 350
22	.02	.02	.02	.02	.02	.02	.02	≤ 350
23	OFF	—	—	—	—	—	OFF	≤ 350
24	.02	.02	.02	.02	.02	.02	.02	≤ 350
25	.02	.02	.02	.02	.02	.02	.02	≤ 350
26	.02	.02	.02	.02	.02	.03	.03	≤ 350
27	.03	.02	.03	.02	.02	.02	.03	≤ 350
28	.02	.02	.02	.03	.03	.03	.03	≤ 350
29	.02	.03	.03	.03	.02	.02	.03	≤ 350
30	.03	.03	.02	.02	.02	.03	.03	≤ 350
31								≤ 350

<b>Conventional or Direct Filtration</b> 95% of turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All turbidity readings < 1 NTU? <u>Yes</u> / No All turbidity readings < IFE triggers? <u>Yes</u> / No <sup>1</sup>		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <u>Yes</u> / No All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No Cl <sub>2</sub> residual measured in 95% of distribution samples? <u>Yes</u> / No		
- OR -		PRINTED NAME: <u>James Ledbetter</u>		
<b>Slow Sand/Cartridge/Membrane/DE Filtration</b> 95% of turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < 5 NTU? <u>Yes</u> / No		SIGNATURE: <u>James Ledbetter</u>		DATE: <u>12-3-2025</u>
		PHONE #: <u>(541) 563-2325</u>		CERT #: <u>T-08795</u>

<sup>1</sup> IFE = Individual Filter Effluent

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Me
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / N
11/0930	0.7	325	228	13	7.5	15	yes
211/100	0.8	325	260	15	7.4	15	yes
36730	0.7	325	228	13	7.5	15	yes
410930	0.7	325	228	15	7.5	15	yes
510930	0.9	325	292	15	7.5	15	yes
610430	0.9	325	292	13	7.5	15	yes
711720	0.8	325	260	15	7.6	15	yes
810930	0.8	325	260	12	7.6	22	yes
9109/5	0.8	325	260	12	7.6	22	yes
1010730	0.9	325	292	13	7.4	15	yes
1110930	0.8	325	260	13	7.6	15	yes
1211800	0.8	325	260	14	7.7	15	yes
1310830	0.7	325	228	12	7.6	22	yes
1410830	0.9	325	292	12	7.4	22	yes
1510830	0.8	325	260	11	7.7	22	yes
1610830	0.8	325	260	15	7.6	15	yes
170730	0.9	325	292	16	7.5	15	yes
1810800	0.9	325	292	14	7.5	15	yes
1910800	1.0	325	325	10	7.5	22	yes
2010530	1.0	325	325	9	7.5	22	yes
2110830	1.0	325	325	11	7.5	22	yes
2211200	0.9	325	292	12	7.7	22	yes
2311930	0.9	325	292	11	7.6	22	yes
2410800	0.7	325	228	10	7.7	22	yes
2510900	1.0	325	325	11	7.6	22	yes
2610830	0.9	325	292	10	7.6	22	yes
2710900	1.0	325	325	10	7.7	22	yes
2810830	1.1	325	358	10	7.6	22	yes
2910815	0.9	325	292	10	7.5	22	yes
3010815	0.9	325	292	10	7.6	22	yes
31/							