

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	OFF	—	—	—	—	—	OFF	≤ 350
2	OFF	—	—	—	—	—	OFF	≤ 350
3	.02	.02	.03	.03	.02	.02	.03	≤ 350
4	OFF	—	—	—	—	—	OFF	≤ 350
5	.02	.02	.02	.02	.03	.02	.03	≤ 350
6	OFF	—	—	—	—	—	OFF	≤ 350
7	.02	.02	.02	.02	.02	.02	.02	≤ 350
8	.02	.02	.02	.02	.02	.02	.02	≤ 350
9	.03	.02	.02	.02	.03	.02	.03	≤ 350
10	.02	.02	.03	.02	.02	.03	.03	≤ 350
11	.02	.02	.02	.02	.02	.02	.02	≤ 350
12	.02	.02	.02	.02	.02	.02	.02	≤ 350
13	.02	.03	.02	.03	.02	.02	.03	≤ 350
14	.03	.02	.02	.02	.02	.02	.03	≤ 350
15	OFF	—	—	—	—	—	OFF	≤ 350
16	OFF	—	—	—	—	—	OFF	≤ 350
17	OFF	—	—	—	—	—	OFF	≤ 350
18	OFF	—	—	—	—	—	OFF	≤ 350
19	.02	.02	.02	.02	.02	.03	.03	≤ 350
20	.03	.03	.03	.02	.03	.02	.03	≤ 350
21	.03	.03	.03	.02	.03	.02	.03	≤ 350
22	.02	.02	.03	.02	.02	.02	.03	≤ 350
23	.02	.02	.02	.02	.02	.02	.02	≤ 350
24	.02	.03	.02	.02	.02	.02	.03	≤ 350
25	.02	.02	.02	.03	.03	.03	.03	≤ 350
26	.03	.02	.02	.02	.02	.02	.03	≤ 350
27	.02	.02	.02	.02	.02	.02	.02	≤ 350
28	.02	.02	.02	.02	.02	.02	.02	≤ 350
29	.02	.02	.02	.02	.02	.03	.03	≤ 350
30	.03	.03	.03	.02	.03	.02	.03	≤ 350
31	.02	.02	.02	.02	.02	.02	.02	≤ 350

Conventional or Direct Filtration 95% of turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ¹		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No Cl ₂ residual measured in 95% of distribution samples? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
- OR -		PRINTED NAME: <u>James Ledbetter</u>		
Slow Sand/Cartridge/Membrane/DE Filtration 95% of turbidity readings ≤ 1 NTU? <input type="radio"/> Yes / <input type="radio"/> No All turbidity readings < 5 NTU? <input type="radio"/> Yes / <input type="radio"/> No		SIGNATURE: <u>James Ledbetter</u>		DATE: <u>2-4-26</u>
		PHONE #: (541) <u>563-2325</u>		CERT #: <u>408795</u>

¹ IFE = Individual Filter Effluent

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met
	ppm or mg/L	minutes	CXT	°C		Use tables	Yes / No
110900	1.2	325	390	7	7.6	22	Yes
2111:30	1.0	325	325	12	7.5	22	Yes
310950	1.2	325	390	10	7.6	22	Yes
411000	1.1	325	358	10	7.6	22	Yes
510800	1.0	325	325	10	7.5	22	Yes
611300	1.0	325	325	8	7.4	22	Yes
710630	1.0	325	325	13	7.5	15	Yes
810630	1.0	325	325	9	7.6	22	Yes
910900	1.0	325	325	12	7.5	22	Yes
1010900	1.1	325	358	6	7.6	22	Yes
1110900	1.1	325	358	9	7.7	22	Yes
1210900	1.3	325	423	11	7.5	22	Yes
1310800	1.0	325	325	10	7.5	22	Yes
1410800	1.0	325	325	10	7.4	22	Yes
1510800	1.0	325	325	10	7.4	22	Yes
1610900	0.9	325	292	11	7.5	22	Yes
1710900	0.9	325	292	11	7.4	22	Yes
1810900	1.0	325	325	10	7.5	22	Yes
19114:30	1.0	325	325	6	7.4	22	Yes
2010900	1.0	325	325	5	7.5	22	Yes
2110830	1.0	325	325	7	7.6	22	Yes
2210830	1.0	325	325	6	7.5	22	Yes
2310900	1.0	325	325	8	7.6	22	Yes
2410800	0.9	325	292	6	7.6	22	Yes
2510800	0.9	325	292	7	7.6	22	Yes
2610930	1.0	325	325	9	7.6	22	Yes
2710730	1.1	325	358	6	7.5	22	Yes
2810800	1.0	325	325	9	7.6	22	Yes
2910800	1.0	325	325	6	7.6	22	Yes
3010800	1.1	325	358	6	7.6	22	Yes
311	0.9	325	292	10	7.6	22	Yes