

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.02	.02	.02	.02	.02	.02	.02	≤ 350
2	.02	.02	.02	.02	.02	.02	.02	≤ 350
3	OFF	---	---	---	---	---	OFF	≤ 350
4	OFF	---	---	---	---	---	OFF	≤ 350
5	OFF	---	---	---	---	---	OFF	≤ 350
6	.02	.03	.02	.02	.02	.02	.03	≤ 350
7	.02	.02	.02	.03	.02	.02	.03	≤ 350
8	.03	.03	.02	.02	.02	.02	.03	≤ 350
9	.02	.02	.02	.02	.02	.02	.02	≤ 350
10	.02	.02	.02	.03	.02	.03	.03	≤ 350
11	OFF	---	---	---	---	---	OFF	≤ 350
12	OFF	---	---	---	---	---	OFF	≤ 350
13	OFF	---	---	---	---	---	OFF	≤ 350
14	OFF	---	---	---	---	---	OFF	≤ 350
15	OFF	---	---	---	---	---	OFF	≤ 350
16	OFF	---	---	---	---	---	OFF	≤ 350
17	.02	.02	.02	.02	.02	.02	.02	≤ 350
18	.02	.03	.02	.02	.02	.02	.03	≤ 350
19	.03	.02	.03	.02	.02	.02	.03	≤ 350
20	.03	.02	.02	.02	.02	.02	.03	≤ 350
21	.02	.02	.02	.02	.02	.02	.02	≤ 350
22	.02	.02	.02	.02	.02	.02	.02	≤ 350
23	.02	.02	.02	.02	.02	.03	.03	≤ 350
24	.02	.03	.02	.02	.02	.02	.03	≤ 350
25	.02	.02	.02	.02	.02	.02	.02	≤ 350
26	.02	.02	.02	.02	.03	.03	.03	≤ 350
27	.03	.03	.02	.02	.02	.03	.03	≤ 350
28	.02	.02	.02	.03	.02	.02	.03	≤ 350
29	.02	.02	.02	.02	.02	.02	.02	≤ 350
30	.02	.02	.02	.02	.02	.02	.02	≤ 350
31	.02	.02	.02	.02	.02	.02	.02	≤ 350

Conventional or Direct Filtration 95% of turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ¹		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No Cl ₂ residual measured in 95% of distribution samples? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
- OR -		PRINTED NAME: <u>James Ledbetter</u>		
Slow Sand/Cartridge/Membrane/DE Filtration 95% of turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < 5 NTU? Yes / No		SIGNATURE: <u>James Ledbetter</u>		DATE: <u>4-2-2026</u>
		PHONE #: <u>(541) 915-3924</u>		CERT #:

¹ IFE = Individual Filter Effluent

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met
	ppm or mg/L	minutes	CXT	°C		Use tables	Yes / No
1 10800	0.9	325	292	12	7.5	22	yes
2 10900	1.0	325	325	10	7.4	22	yes
3 11000	1.0	325	325	10	7.4	22	yes
4 10830	1.1	325	358	11	7.4	22	yes
5 10830	1.1	325	358	12	7.4	22	yes
6 10930	1.0	325	325	10	7.4	22	yes
7 10850	1.0	325	325	11	7.4	22	yes
8 10930	0.9	325	292	12	7.5	22	yes
9 10830	1.0	325	325	10	7.5	22	yes
10 10900	1.1	325	358	11	7.4	22	yes
11 10800	1.1	325	358	11	7.5	22	yes
12 10800	1.0	325	325	12	7.4	22	yes
13 10900	1.1	325	358	12	7.4	22	yes
14 10845	0.9	325	292	8	7.5	22	yes
15 10940	0.9	325	292	10	7.4	22	yes
16 11100	1.0	325	325	9	7.4	22	yes
17 1900	1.0	325	325	9	7.4	22	yes
18 10900	1.0	325	325	10	7.6	22	yes
19 10900	1.0	325	325	10	7.5	22	yes
20 10900	1.0	325	325	12	7.5	22	yes
21 10900	1.1	325	358	13	7.5	15	yes
22 10900	1.1	325	358	11	7.4	22	yes
23 10900	1.1	325	358	10	7.4	22	yes
24 10900	1.0	325	325	12	7.5	22	yes
25 10830	1.1	325	358	10	7.5	22	yes
26 10830	1.1	325	358	9	7.4	22	yes
27 11000	1.1	325	358	8	7.4	22	yes
28 1930	0.9	325	292	12	7.5	22	yes
29 10910	1.0	325	325	13	7.5	15	yes
30 10900	1.0	325	325	14	7.4	15	yes
31 10930	1.0	325	325	13	7.5	15	yes