

Oregon DHS - Drinking Water Program -- Turbidity Monitoring Report Form

System Name: *City of Waldport*

ID #: 41 00926

Month/Year: 04/22

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1	.05	.05	off	off	off	.06	2.06	< 350
2	.05	.05	.05	.05	.05	.05	2.05	< 350
3	off	off	.05	.05	.05	off	2.05	< 350
4	off	off	.05	off	.06	.05	2.06	< 350
5	.05	.05	.05	.05	.05	.05	2.05	< 350
6	.06	.06	.06	.05	.05	.05	2.06	< 350
7	.05	.05	off	.05	.06	off	2.06	< 350
8	off	off	.05	.05	.05	.05	2.05	< 350
9	.05	.05	.05	.05	.05	.05	2.05	< 350
10	off	off	.05	.05	.06	off	2.06	< 350
11	off	off	.05	.05	.05	.06	2.06	< 350
12	off	off	.05	.05	.05	.06	2.06	< 350
13	.07	off	.05	.05	.05	.05	2.07	< 350
14	.05	.05	.06	.05	.05	.05	2.06	< 350
15	.05	.05	.05	.05	.05	.05	2.05	< 350
16	.05	.05	.05	.05	off	.05	2.05	< 350
17	.05	.05	.05	.05	.05	off	2.05	< 350
18	off	off	off	off	off	off	0	< 350
19	off	off	.05	.05	.05	.05	2.05	< 350
20	.05	.05	.05	.05	.05	.05	2.05	< 350
21	.05	.05	.05	.06	.05	.05	2.06	< 350
22	.05	.05	.05	.05	.06	.05	2.06	< 350
23	.05	.05	.05	.05	.05	.05	2.05	< 350
24	off	off	.05	.05	.05	.05	2.05	< 350
25	off	off	.05	.05	.05	.05	2.05	< 350
26	.05	.06	.05	.05	.05	off	2.06	< 350
27	off	off	.05	.05	.05	.05	2.05	< 350
28	.05	.05	.05	.05	.06	off	2.06	< 350
29	off	off	off	off	off	off	0	< 350
30	off	off	.07	.06	.05	.06	2.07	< 350
31								

Conventional or Direct Filtration 95% of turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ¹		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No Cl ₂ residual measured in 9 of distribution samples? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
- OR -		PRINTED NAME: <i>Lyle T. Arrant</i>		
Slow Sand/Cartridge/Membrane/DE Filtration 95% of turbidity readings ≤ 1 NTU? <input type="radio"/> Yes / <input type="radio"/> No All turbidity readings < 5 NTU? <input type="radio"/> Yes / <input type="radio"/> No		SIGNATURE: <i>Lyle T. Arrant</i>		DATE: 05/02/22
		PHONE #: 541 1563-2929		CERT #: 5292

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name: *City of Waldport* ID #: *41 00926* Month/Year: *04/20*

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT
	ppm or mg/L	minutes	CXT	°C		Use tables	Yes
110845	1.0	360	360	12	7.3	22	Yes
2110905	0.9	360	324	13	7.3	15	Yes
310800	0.9	360	324	13	7.4	15	Yes
411500	1.0	360	360	13	7.6	15	Yes
511700	0.9	360	324	13	7.6	15	Yes
611730	0.9	360	324	13	7.5	15	Yes
711630	0.9	360	324	13	7.4	15	Yes
810930	0.9	360	324	12	7.4	22	Yes
910930	1.0	360	360	15	7.4	15	Yes
1010745	0.9	360	324	14	7.4	15	Yes
1111800	1.0	360	360	13	7.6	15	Yes
1211600	1.0	360	360	13	7.5	15	Yes
1311730	1.0	360	360	13	7.6	15	Yes
1411800	1.0	360	360	13	7.6	15	Yes
1511500	0.9	360	324	12	7.5	22	Yes
1610930	0.8	360	288	14	7.6	15	Yes
1710905	0.9	360	324	12	7.5	22	Yes
18110130	0.9	360	324	13	7.5	15	Yes
1911800	0.9	360	324	13	7.6	15	Yes
2011630	0.9	360	324	13	7.6	15	Yes
2111700	0.9	360	324	11	7.5	22	Yes
2211005	0.9	360	324	14	7.6	15	Yes
2310915	0.8	360	288	15	7.5	15	Yes
24109145	0.9	360	324	17	7.5	15	Yes
2511600	1.0	360	360	13	7.6	15	Yes
2611530	1.0	360	360	13	7.6	15	Yes
2710840	1.0	360	360	12	7.4	22	Yes
2810830	0.8	360	288	18	7.5	11	Yes
2911600	0.9	360	324	14	7.5	15	Yes
3011800	1.0	360	360	15	7.5	15	Yes
311							