


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clatsop
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

SYSTEM NAME: **Warrenton** ID#: **4100932-A** Month/Year **January 2021**

DAY	12AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.03	0.02	0.02	0.03
9	0.02	0.02	0.03	0.02	0.02	0.02	0.03
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	0.02	0.02	0.03	0.04	0.04	0.02	0.04
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02
19	0.02	0.03	0.03	0.02	0.02	0.02	0.03
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.03	0.02	0.02	0.02	0.03
24	0.03	0.03	0.04	0.03	0.03	0.03	0.04
25	0.03	0.02	0.03	0.03	0.02	0.02	0.03
26	0.03	0.03	0.03	0.02	0.02	0.02	0.03
27	0.02	0.02	0.03	0.02	0.02	0.02	0.03
28	0.02	0.02	0.03	0.02	0.02	0.02	0.03
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Membrane	Monthly Summary (Answers Yes or No)	
95% of Daily Turbidity Readings < 1 NTU YES Daily Turbidity readings < 5 NTU YES	All	CT's met everyday? YES All CL ₂ Residual at entry point > 0.2 mg/l YES
NOTES:	PRINTED NAME: Dave Davis	
	SIGNATURE: 	DATE: Feb.1,2021
	PHONE #: (503) 738-7809	CERT #: T-08549

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

SYSTEM NAME: **Warrenton**

ID# **4100932**

Month/Year **January 2021**

Date / Time	Min. Cl ₂ Residual At 1st User (C) (ppm or mg/l)	Clearwell Volume (MG)	Contact Time (T) (minutes)	Actual CT (C x T)	Temp °C	pH	Required CT (CT Tables)	CT Met Yes / No	Peak Hourly Flow (gpm)
1 / 7:30	1.2	3.3	335	402	5	7.5	31	yes	788
2 / 7:30	1.2	3.3	331	397	5	7.5	31	yes	798
3 / 7:30	1.2	3.3	342	410	5	7.5	31	yes	772
4 / 7:30	1.2	3.3	347	417	5	7.5	31	yes	760
5 / 7:30	1.2	3.3	350	420	5	7.5	31	yes	754
6 / 7:30	1.2	3.3	346	415	5	7.5	31	yes	764
7 / 7:30	1.2	3.3	346	415	5	7.5	31	yes	763
8 / 7:30	1.2	3.3	350	420	5	8.0	37	yes	754
9 / 7:30	1.2	3.2	345	414	5	8.0	37	yes	742
10 / 7:30	1.2	3.3	358	429	5	8.0	37	yes	738
11 / 7:30	1.2	3.3	353	424	5	8.0	37	yes	747
12 / 7:30	1.2	3.3	191	230	5	8.0	37	yes	1380
13 / 7:30	1.2	2.9	312	374	5	8.0	37	yes	744
14 / 7:30	1.2	3	318	382	5	8.0	37	yes	754
15 / 7:30	1.2	3.2	322	387	10	8.0	28	yes	794
16 / 7:30	1.2	3.3	330	395	5	7.5	31	yes	801
17 / 7:30	1.2	3.3	337	405	5	7.5	31	yes	783
18 / 7:30	1.2	3.3	332	398	5	7.5	31	yes	796
19 / 7:30	1.2	3.3	331	397	5	7.5	31	yes	798
20 / 7:30	1.2	3.3	336	403	5	7.5	31	yes	787
21 / 7:30	1.2	3.3	345	414	5	7.5	31	yes	765
22 / 7:30	1.2	3.3	345	414	5	8.0	37	yes	765
23 / 7:30	1.2	3.3	350	420	5	8.0	37	yes	754
24 / 7:30	1.2	3.3	373	447	5	8.0	37	yes	709
25 / 7:30	1.2	3.3	369	442	5	8.0	37	yes	716
26 / 7:30	1.2	3.3	350	420	5	8.0	37	yes	754
27 / 7:30	1.2	2.9	318	381	5	8.0	37	yes	731
28 / 7:30	1.2	3.3	357	429	5	8.0	37	yes	739
29 / 7:30	1.2	3.3	367	440	5	8.0	37	yes	720
30 / 7:30	1.2	3.3	365	439	5	8.0	37	yes	722
31 / 7:30	1.2	3.3	391	469	5	8.0	37	yes	676

If CL₂ at entry point < 0.2 mg/l OR CT not met, DWP by end of next business day.

PRINT NAME: Dave Davis

SIGNATURE: 

DATE: Feb. 1, 2021

CERT#: T-08549

PHONE#: (503) 738-7809