

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clapsop  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

SYSTEM NAME: **Warrenton** ID#: **4100932-A** Month/Year **Feb. 2023**

DAY	12AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
<b>1</b>	0.06	0.06	0.06	0.05	0.05	0.06	0.06
<b>2</b>	0.06	0.06	0.06	0.07	0.07	0.07	0.07
<b>3</b>	0.05	0.05	0.04	0.04	0.06	0.06	0.06
<b>4</b>	0.05	0.05	0.06	0.05	0.05	0.05	0.06
<b>5</b>	0.04	0.04	0.04	0.04	0.04	0.06	0.06
<b>6</b>	0.05	0.05	0.05	0.06	0.06	0.05	0.06
<b>7</b>	0.06	0.05	0.05	0.06	0.05	0.05	0.06
<b>8</b>	0.05	0.04	0.05	0.04	0.04	0.05	0.05
<b>9</b>	0.05	0.04	0.04	0.05	0.05	0.05	0.05
<b>10</b>	0.05	0.05	0.04	0.04	0.05	0.05	0.05
<b>11</b>	0.04	0.05	0.06	0.05	0.06	0.05	0.06
<b>12</b>	0.05	0.05	0.04	0.05	0.04	0.04	0.05
<b>13</b>	0.04	0.05	0.05	0.04	0.05	0.04	0.05
<b>14</b>	0.06	0.05	0.04	0.05	0.05	0.04	0.06
<b>15</b>	0.04	0.05	0.04	0.05	0.04	0.04	0.05
<b>16</b>	0.04	0.04	0.04	0.04	0.04	0.05	0.05
<b>17</b>	0.04	0.04	0.11	0.08	0.04	0.07	0.11
<b>18</b>	0.05	0.05	0.05	0.04	0.05	0.05	0.05
<b>19</b>	0.05	0.04	0.06	0.05	0.06	0.05	0.06
<b>20</b>	0.04	0.05	0.06	0.05	0.04	0.04	0.06
<b>21</b>	0.05	0.04	0.04	0.06	0.04	0.04	0.06
<b>22</b>	0.04	0.04	0.04	0.04	0.05	0.05	0.05
<b>23</b>	0.05	0.05	0.05	0.05	0.04	0.05	0.05
<b>24</b>	0.04	0.05	0.05	0.05	0.04	0.05	0.05
<b>25</b>	0.04	0.03	0.04	0.04	0.05	0.05	0.05
<b>26</b>	0.05	0.04	0.04	0.04	0.04	0.05	0.05
<b>27</b>	0.04	0.04	0.05	0.05	0.04	0.04	0.05
<b>28</b>	0.05	0.04	0.04	0.05	0.04	0.04	0.05
<b>29</b>							
<b>30</b>							
<b>31</b>							

<b>Membrane</b>	<b>Monthly Summary (Answers Yes or No)</b>	
95% of Daily Turbidity Readings < 1 NTU <b>YES</b> Daily Turbidity readings < 5 NTU <b>YES</b>	All <b>CT's met everyday? YES</b>	All CL <sub>2</sub> Residual at entry point > 0.2 mg/l <b>YES</b>
<b>NOTES:</b>	<b>PRINTED NAME: Dave Davis</b>	
	<b>SIGNATURE:</b> 	<b>DATE: 3-1-2023</b>
	<b>PHONE #: (503) 738-7809</b>	<b>CERT #: T-08549</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

SYSTEM NAME: **Warrenton**

ID# **4100932**

Month/Year **FEB. 2023**

Date / Time	Min. Cl <sub>2</sub> Residual At 1st User (C) (ppm or mg/l)	Clearwell Volume (MG)	Contact Time (T) (minutes)	Actual CT (C x T)	Temp °C	pH	Required CT (CT Tables)	CT Met Yes / No	Peak Hourly Flow (gpm)
1 / 7:30	1.2	3.3	341	409	5	8.5	45	yes	774
2 / 7:30	1.2	3.3	341	409	5	7.5	31	yes	774
3 / 7:30	1.2	3.3	348	417	5	7.5	31	yes	759
4 / 7:30	1.2	3.3	358	429	5	7.5	31	yes	738
5 / 7:30	1.2	3.3	373	447	5	7.5	31	yes	709
6 / 7:30	1.2	3.3	358	429	5	7.5	31	yes	738
7 / 7:30	1.2	3.3	356	427	5	7.5	31	yes	743
8 / 7:30	1.2	3.3	337	389	5	7.5	31	yes	784
9 / 7:30	1.4	3.3	313	438	5	7.5	31	yes	844
10 / 7:30	1.2	3.3	313	366	5	7.5	31	yes	842
11 / 7:30	1.2	3.3	318	381	5	7.5	31	yes	831
12 / 7:30	1.2	3.3	327	392	5	7.5	31	yes	808
13 / 7:30	1.2	3.3	344	423	5	7.5	31	yes	768
14 / 7:30	1.2	3.3	361	433	5	7.5	31	yes	732
15 / 7:30	1.2	3.3	356	440	5	7.5	31	yes	742
16 / 7:30	1.2	3.3	360	416	5	7.5	31	yes	733
17 / 7:30	1.2	3.3	350	420	5	7.5	31	yes	754
18 / 7:30	1.2	3.3	350	420	5	7.5	31	yes	754
19 / 7:30	1.2	3.3	358	430	5	7.5	31	yes	737
20 / 7:30	1.2	3.3	347	417	5	7.5	31	yes	760
21 / 7:30	1.2	3.3	361	419	5	7.5	31	yes	732
22 / 7:30	1.2	3.3	363	421	5	7.5	31	yes	728
23 / 7:30	1.2	3.3	365	421	5	7.5	31	yes	724
24 / 7:30	1.2	3.3	350	406	0.5	7.5	43	yes	754
25 / 7:30	1.2	3.3	347	405	0.5	8.0	52	yes	762
26 / 7:30	1.2	3.3	376	434	5	7.5	31	yes	702
27 / 7:30	1.2	3.3	366	439	5	7.5	31	yes	722
28 / 7:30	1.2	3.3	368	441	5	7.5	31	yes	718

If Cl<sub>2</sub> at entry point < 0.2 mg/l OR CT not met, DWP by end of next business day.

PRINT NAME: Dave Davis

SIGNATURE: 

DATE: **3-1-2023**

CERT#: T-08549

PHONE#: **(503)738-7809**

# DAILY TURBIDITY, CHLORINE, AND PRODUCTION REPORT

SYSTEM NAME: **Warrenton** ID# **4100932** PLANT OPERATOR: Dave Davis MONTH/YEAR Feb. 2023

DAY	TIME	Water Prod.(x-1000,MGD)			N.T.U.		Temp	CL2 Test (0.8% Sodium Hypochlorite)					PH	Fluoride	ACH
		Feed Flow	Backwash water	Waste-Flow	Raw Water	Filtrate Water	Water Temp C°	Dosage Setting	Chlorine Used (gals.)	Dry Pounds (lbs)	Dist CL2 mg/l	CL2 Lab Sample	Filtrate PH	Fluoride Residual	Dosage mg/l Setting
1	7:30	1303	234	1069	3.5	0.03	5	1.4	181	12	1.1	1.1	8.1	0.7	7
2	7:30	1280	261	1019	11.5	0.03	6	1.3	169	11	1.1	1.1	7.5	0.7	7
3	7:30	1269	243	1026	3.2	0.03	6	1.3	164	11	1.1	1.1	7.3	0.8	7
4	7:30	1205	222	983	2.4	0.03	7	1.3	156	10	1.1	1.1	7.3	0.8	7
5	7:30	1192	228	964	3.7	0.03	7	1.3	155	10	1.1	1.1	7.2	0.8	7
6	7:30	1160	213	947	2.6	0.03	7	1.4	160	11	1.1	1.1	7.2	0.7	7
7	7:30	1231	224	1007	3.3	0.03	8	1.4	173	12	1.1	1.1	7.3	0.7	7
8	7:30	1232	231	1001	2.3	0.04	7	1.4	169	11	1.2	1.1	7.3	0.7	7
9	7:30	1339	236	1103	1.4	0.03	7	1.3	180	12	1.3	1.1	7.3	0.8	7
10	7:30	1328	235	1093	1.8	0.03	8	1.2	168	11	1.2	1.1	7.2	0.9	7
11	7:30	1336	230	1106	1.8	0.03	7	1.2	162	11	1.1	1.1	7.2	0.8	7
12	7:30	1316	229	1087	0.6	0.04	6	1.2	159	11	1.1	1.2	7.4	0.7	7
13	7:30	1233	210	1023	0.7	0.03	6	1.2	153	10	1.2	1.2	7.3	0.7	7
14	7:30	1195	218	977	1.8	0.03	5	1.2	144	10	1.1	1.2	7.2	0.7	7
15	7:30	1174	211	963	1.3	0.03	5	1.3	144	10	1.2	1.1	7.3	0.6	7
16	7:30	1190	208	982	1.4	0.03	5	1.4	161	11	1.2	1.1	7.4	0.6	7
17	7:30	1178	208	970	1.6	0.03	6	1.4	163	11	1.1	1.1	7.4	0.7	7
18	7:30	1225	223	1002	1.7	0.03	6	1.5	175	12	1.1	1.1	7.3	0.7	7
19	7:30	1176	204	972	1.8	0.03	7	1.5	172	11	1.1	1.1	7.4	0.7	7
20	7:30	1202	218	984	2.2	0.03	7	1.5	175	12	1.1	1.1	7.5	0.7	7
21	7:30	1221	226	995	2.5	0.03	6	1.5	174	12	1.2	1.1	7.5	0.7	7
22	7:30	1196	217	979	2.9	0.03	6	1.5	170	11	1.2	1.1	7.4	0.7	7
23	7:30	1173	213	960	1.7	0.03	5	1.4	164	11	1.2	1.1	7.4	0.7	7
24	7:30	1198	214	984	1.3	0.03	4	1.4	161	11	1.2	1.1	7.4	0.7	7
25	7:30	1201	215	986	1.5	0.03	4	1.4	155	10	1.2	1.1	7.6	0.7	7
26	7:30	1149	216	933	2.5	0.03	5	1.4	149	10	1.2	1.1	7.4	0.7	7
27	7:30	1143	206	937	1.8	0.03	5	1.3	148	10	1.1	1.1	7.5	0.8	7
28	7:30	1159	214	945	1.7	0.03	5	1.3	145	10	1.1	1.1	7.4	0.7	7
Total		34204	6207	27997	66.8	0.84	168	37.9	4549	305	31.8	31.1	206.4	20.2	N/A
Minimum		1143	204	933	0.6	0.03	4	1.2	144	10	1.1	1.1	7.2	0.6	
Maximum		1339	261	1106	11.5	0.04	8	1.5	181	12	1.3	1.2	8.1	0.9	
Average		1222	222	1000	2.4	0.03	6	1.4	162	11	1.1	1.1	7.4	0.7	

DATE: **3-1-2023**

CERT#: **T-08549**

PHONE #: **(503)738-7809**

SIGNATURE:

