

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Clatsop
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

SYSTEM NAME: **Warrenton** ID#: **4100932-A** Month/Year **Nov.2023**

DAY	12AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.04	0.04
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Membrane		Monthly Summary (Answers Yes or No)		
95% of Daily Turbidity Readings < 1 NTU	YES	All	CT's met everyday?	YES
Daily Turbidity readings < 5 NTU	YES		All CL ₂ Residual at entry point > 0.2 mg/l	YES
NOTES:		PRINTED NAME: Dave Davis		
		SIGNATURE: 	DATE: 12-4-2023	
		PHONE #: (503) 738-7809		CERT #: T-08549

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM"

through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form
SYSTEM NAME: Warrenton ID#4100932 Month/Year Nov. 2023

Date / Time	Min. Cl ₂ Residual At 1st User (C)	Clearwell Volume	Contact Time (T)	Actual CT	Temp °C	pH	Required CT	CT Met	Peak Hourly Flow
	(ppm or mg/l)	(MG)	(minutes)	(C x T)			(CT Tables)	Yes / No	(gpm)
1 / 7:30	1.2	3.3	309	357	5.0	6.5	21	yes	853
2 / 7:30	1.2	3.3	304	365	10.0	6.5	16	yes	869
3 / 7:30	1.0	3.3	310	311	10.0	6.5	16	yes	852
4 / 7:30	1.2	3.3	309	357	10.0	6.5	16	yes	853
5 / 7:30	1.2	3.3	320	384	10.0	6.5	16	yes	825
6 / 7:30	1.4	3.3	318	446	10.0	6.5	16	yes	830
7 / 7:30	1.2	3.3	320	383	10.0	6.5	16	yes	825
8 / 7:30	1.2	3.3	320	384	10.0	6.5	16	yes	824
9 / 7:30	1.2	3.3	314	377	5.0	6.5	21	yes	841
10 / 7:30	1.2	3.3	310	372	10.0	7.0	19	yes	851
11 / 7:30	1.2	3.3	314	377	10.0	7.0	19	yes	840
12 / 7:30	1.2	3.3	315	379	10.0	6.5	16	yes	837
13 / 7:30	1.2	3.3	307	368	10.0	6.5	16	yes	861
14 / 7:30	1.2	3.3	308	358	5.0	6.5	21	yes	857
15 / 7:30	1.2	3.3	309	359	5.0	7.0	25	yes	854
16 / 7:30	1.2	3.3	313	375	5.0	7.0	25	yes	844
17 / 7:30	1.2	3.3	317	381	5.0	7.0	25	yes	832
18 / 7:30	1.2	3.3	320	384	5.0	7.0	25	yes	825
19 / 7:30	1.2	3.3	319	382	5.0	7.0	25	yes	829
20 / 7:30	1.2	3.3	315	379	5.0	7.0	25	yes	837
21 / 7:30	1.2	3.3	308	369	5.0	7.5	31	yes	858
22 / 7:30	1.2	3.3	292	351	5.0	7.5	31	yes	904
23 / 7:30	1.2	3.3	291	349	5.0	7.5	31	yes	908
24 / 7:30	1.0	3.3	308	315	5.0	7.5	30	yes	858
25 / 7:30	1.2	3.3	309	371	5.0	7.5	31	yes	853
26 / 7:30	1.2	3.3	286	343	5.0	7.0	25	yes	924
27 / 7:30	1.2	3.3	304	364	5.0	7.0	25	yes	870
28 / 7:30	1.2	3.3	305	356	5.0	7.0	25	yes	866
29 / 7:30	1.2	3.3	312	367	5.0	7.0	25	yes	845
30 / 7:30	1.2	3.3	312	375	5.0	7.0	25	yes	847

If CL₂ at entry point < 0.2 mg/l OR CT not met, DWP by end of next business day.

PRINT NAME: Dave Davis

SIGNATURE: 

DATE: 12-4-2023

CERT#: T-08549

PHONE#: (503)738-7809

DAILY TURBIDITY, CHLORINE, AND PRODUCTION REPORT

SYSTEM NAME: **Warrenton** ID# **4100932** PLANT OPERATOR: Dave Davis MONTH/YEAR NOV. 2023

DAY	TIME	Water Prod.(x-1000, MGD)			N.T.U.		Temp	CL2 Test (0.8% Sodium Hypochlorite)					PH	Fluoride	ACH
		Feed Flow	Backwash Waste-water	Filtrate Flow	Raw Water	Filtrate Water	Water Temp C°	Dosage Setting	Chlorine Used (gals.)	Dry Pounds (lbs)	Dist CL2 mg/l	CL2 Lab Sample	Filtrate PH	Fluoride Residual	Dosage mg/l Setting
1	7:30	1323	171	1152	1.6	0.03	8	1.5	218	15	1.2	1.1	6.5	0.8	7
2	7:30	1351	178	1173	5.6	0.03	11	2	274	18	1.1	1.1	6.3	0.8	7
3	7:30	1326	165	1161	2.7	0.03	11	2.1	309	21	1.0	1.1	6.4	0.7	7
4	7:30	1330	165	1165	3.9	0.03	12	2.1	314	21	1.2	1.0	6.3	0.6	7
5	7:30	1262	154	1108	3.7	0.03	11	2	284	19	1.1	1.1	6.3	0.6	7
6	7:30	1286	177	1109	6.6	0.03	11	1.6	243	16	1.3	1.2	6.2	0.7	7
7	7:30	1291	166	1125	3.9	0.03	11	1.6	230	15	1.2	1.1	6.1	0.7	7
8	7:30	1252	158	1094	3.2	0.03	10	1.4	208	14	1.1	1.1	6.3	0.7	7
9	7:30	1286	167	1119	1.9	0.03	9	1.4	200	13	1.1	1.1	6.4	0.7	7
10	7:30	1326	166	1160	2.2	0.03	10	1.5	217	14	1.1	1.1	6.4	0.7	7
11	7:30	1290	153	1137	3.5	0.03	10	1.5	219	15	1.1	1.1	6.6	0.8	7
12	7:30	1293	162	1131	2.0	0.03	10	1.6	226	15	1.1	1.1	7.0	0.8	7
13	7:30	1298	159	1139	2.2	0.03	10	1.6	235	16	1.1	1.1	6.3	0.8	7
14	7:30	1317	164	1153	1.6	0.03	9	1.5	228	15	1.2	1.1	6.4	0.8	7
15	7:30	1324	169	1155	1.4	0.03	9	1.4	215	14	1.2	1.1	6.4	0.8	7
16	7:30	1292	167	1125	1.5	0.03	9	1.4	205	14	1.1	1.0	6.7	0.8	7
17	7:30	1292	152	1140	1.5	0.03	9	1.5	216	14	1.1	1.1	6.8	0.8	7
18	7:30	1291	156	1135	1.5	0.03	9	1.5	220	15	1.1	1.1	6.8	0.8	7
19	7:30	1235	151	1084	1.6	0.03	9	1.6	218	15	1.1	1.1	6.9	0.8	7
20	7:30	1284	163	1121	1.5	0.03	9	1.6	232	15	1.1	1.1	6.9	0.8	7
21	7:30	1317	160	1157	1.5	0.03	8	1.6	240	16	1.1	1.1	7.1	0.7	7
22	7:30	1357	161	1196	1.7	0.03	8	1.6	251	17	1.1	1.1	7.4	0.7	7
23	7:30	1371	162	1209	1.6	0.03	8	1.6	251	17	1.1	1.1	7.4	0.8	7
24	7:30	1315	157	1158	1.6	0.03	8	1.6	167	11	1.0	1.1	7.2	0.8	7
25	7:30	1333	165	1168	1.5	0.03	7	1.6	232	15	1.1	1.1	7.5	0.8	7
26	7:30	1338	160	1178	1.4	0.03	7	1.6	234	16	1.1	1.1	7.0	0.8	7
27	7:30	1321	161	1160	1.4	0.03	7	1.6	230	15	1.1	1.1	6.9	0.8	7
28	7:30	1333	159	1174	1.3	0.03	6	1.6	230	15	1.2	1.1	6.9	0.8	7
29	7:30	1342	171	1171	1.3	0.03	6	1.6	227	15	1.2	1.1	6.9	0.8	7
30	7:30	1309	153	1156	1.2	0.03	6	1.6	228	15	1.2	1.1	6.8	0.7	7
Total		39285	4872	34413	68.1	0.91	266	48.4	7001	466	33.9	32.9	201.3	22.6	N/A
Minimum		1235	151	1084	1.2	0.03	6	1.4	167	11	1.0	1.0	6.1	0.6	
Maximum		1371	178	1209	6.6	0.03	12	2.1	314	21	1.3	1.2	7.5	0.8	
Average		1310	162	1147	2.3	0.03	9	1.6	233	16	1.1	1.1	6.7	0.8	

DATE: **12-4-2023** CERT#: **T-08549**

PHONE #: **(503)738-7809** SIGNATURE:

