



# OHA-DWS

## Disinfection Monthly Operating Report

System Name: Winston Dillard Water District

PWS ID#: 41 - 00957

Plant ID : WTP - 4100957

**0.5**

↔ Log  
Inactivation  
Required via  
Disinfection

Day	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) ♦ [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? ♦ [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	1.12	57.7	64.6	6.7	8.25	38.2	YES	1,263	
2	1.33	57.8	76.9	7.3	7.73	31.1	YES	1,260	
3	1.35	57.8	78.0	7.7	8.01	33.6	YES	1,260	
4	1.30	57.7	75.0	7.8	7.98	32.8	YES	1,262	
5	1.31	57.9	75.8	8.0	7.68	29.0	YES	1,259	
6	1.25	59.4	74.3	8.5	7.66	27.7	YES	1,226	
7	1.13	58.3	65.9	9.3	7.70	26.2	YES	1,250	
8	1.15	57.8	66.5	8.3	7.45	25.7	YES	1,260	
9	1.21	58.4	70.7	7.8	7.36	25.9	YES	1,248	
10	1.69	58.7	99.2	7.5	7.37	28.1	YES	1,242	
11	1.45	57.8	83.8	7.3	7.39	27.9	YES	1,261	
12	1.59	57.9	92.1	7.5	7.47	28.8	YES	1,258	
13	1.40	58.5	81.9	7.6	7.40	27.3	YES	1,245	
14	1.40	56.9	79.7	8.6	7.57	27.1	YES	1,281	
15	1.15	58.6	67.4	8.7	7.48	25.3	YES	1,243	
16	1.33	58.0	77.1	8.8	7.54	26.2	YES	1,255	
17	1.31	58.0	76.0	7.5	7.60	29.2	YES	1,255	
18	1.15	58.5	67.3	7.2	7.64	29.7	YES	1,245	
19	1.31	58.0	76.0	6.9	7.68	31.3	YES	1,255	
20	1.24	58.0	71.9	7.0	7.60	29.9	YES	1,256	
21	1.32	58.7	77.5	7.2	7.65	30.4	YES	1,241	
22	1.43	60.5	86.5	7.3	7.60	30.0	YES	1,204	
23									off
24									off
25	1.14	58.0	66.1	9.6	7.39	23.1	YES	1,256	
26	1.32	58.0	76.6	9.2	7.24	22.9	YES	1,257	
27	1.49	65.1	97.0	9.2	7.27	23.6	YES	1,119	
28	1.28	60.5	77.4	10.1	7.28	21.8	YES	1,204	

♦ If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

**Submit this monthly report by the 10<sup>th</sup> of following month by**

mail: Drinking Water Services  
PO Box 14350  
Portland, OR 97293-0350

email: [dwp.dmce@odhsoha.oregon.gov](mailto:dwp.dmce@odhsoha.oregon.gov)

fax: 971-673-0458

# Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: **Winston Dillard Water Dist.**

ID# **41 00957**

Month/Year: **Feb / 2026**

Minimum UVT [%] during month: 90.7%

Duty sensor variation from reference sensor %: 18.5%

Minimum Validated UVT : 70% {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[ <sup>mW</sup> /cm <sup>2</sup> ]	[ Y or N ]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1	1,263	7.4	Y	541,231	None	
2	1,260	7.6	Y	631,472	None	
3	1,260	7.5	Y	537,228	None	
4	1,262	7.2	Y	486,529	None	
5	1,259	7.9	Y	191,187	None	
6	1,226	7.4	Y	805,793	None	
7	1,250	7.4	Y	473,832	None	
8	1,260	6.0	Y	645,215	None	
9	1,248	6.1	Y	507,425	None	
10	1,242	6.0	Y	640,728	None	
11	1,261	6.9	Y	584,787	None	
12	1,258	7.3	Y	97,184	None	
13	1,245	7.4	Y	881,839	None	
14	1,281	7.3	Y	546,310	None	
15	1,243	7.3	Y	290,644	None	
16	1,255	7.2	Y	773,528	None	
17	1,255	6.4	Y	605,678	None	
18	1,245	6.4	Y	514,178	None	
19	1,255	6.9	Y	567,532	None	
20	1,256	7.0	Y	623,164	None	
21	1,241	6.9	Y	536,420	None	
22	1,204	6.8	Y	593,915	None	
23	off	off	N	off	None	
24	off	off	N	off	None	
25	1,256	6.1	Y	759,543	None	
26	1,257	7.0	Y	711,155	None	
27	1,119	7.1	Y	399,795	None	
28	1,204	7.3	Y	525,294	None	
Monthly Cumulative % Off-Spec Water Produced						None

Signature: *Derek Osterman*

Op Cert #: T 08919

Date: 3/2/2026