

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Douglas**
 Month/Year: **Feb-26**

Conventional or Direct Filtration

System Name:	City of Yoncalla		ID#: 41 00958				WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8AM (NTU)	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	0.07	0.07	0.05	NIS	NIS	NIS	0.07	
2	NIS	0.07	0.07	0.06	0.07	0.06	0.07	
3	NIS	NIS	0.10	0.07	NIS	NIS	0.10	
4	NIS	0.08	0.08	0.06	NIS	NIS	0.08	
5	NIS	NIS	0.07	0.06	0.08	NIS	0.08	
6	NIS	0.07	NIS	NIS	NIS	NIS	0.07	
7	NIS	NIS	0.08	0.07	0.07	0.07	0.08	
8	0.07	0.08	0.06	NIS	NIS	NIS	0.08	
9	NIS	0.06	0.06	0.06	0.10	0.06	0.10	
10	NIS	NIS	0.08	0.07	NIS	NIS	0.08	
11	NIS	NIS	0.06	0.08	0.05	NIS	0.08	
12	NIS	NIS	0.06	0.07	0.05	NIS	0.07	
13	NIS	NIS	0.05	0.06	NIS	NIS	0.06	
14	NIS	NIS	NIS	0.25	0.08	NIS	0.25	
15	NIS	NIS	0.09	0.07	0.13	NIS	0.13	
16	NIS	0.07	0.07	0.09	0.07	0.13	0.13	
17	0.08	NIS	NIS	NIS	0.07	NIS	0.08	
18	NIS	NIS	NIS	0.08	0.05	NIS	0.08	
19	NIS	NIS	NIS	0.05	0.07	0.07	0.07	
20	0.07	0.07	0.05	NIS	NIS	NIS	0.07	
21	NIS	NIS	NIS	NIS	NIS	NIS	OFF	
22	NIS	NIS	0.76	NIS	NIS	NIS	0.76	
23	NIS	NIS	0.05	0.09	0.07	NIS	0.09	
24	0.07	0.07	NIS	NIS	0.05	0.07	0.07	
25	.0.8	NIS	NIS	NIS	0.05	0.08	0.08	
26	0.07	NIS	NIS	0.05	NIS	NIS	0.08	
27	NIS	NIS	NIS	NIS	0.06	0.07	0.07	
28	NIS	NIS	0.07	0.08	NIS	0.09	0.09	
29								
30								

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:	PRINTED NAME: Darrel Lockard	
	SIGNATURE: <i>Darrel Lockard</i>	03/10/26
	PHONE # (541)222*9997	CERT#2853

correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Yoncalla	ID#: 41 00958	Month/Year:	Feb-26	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	------------------	---------------	-------------	--------	---	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.09	63	68.7	7.3	7.60	28.8	YES	469
2	1.17	63	73.7	7.6	7.60	28.5	YES	469
3	1.15	63	72.5	7.5	7.10	24.0	YES	469
4	1.08	63	68.0	7.7	7.30	25.2	YES	469
5	1.16	63	73.1	7.6	7.30	25.6	YES	469
6	1.2	63	75.6	7.9	7.50	27.1	YES	469
7	1.22	63	76.9	8.3	7.50	26.4	YES	469
8	1.14	63	71.8	8.2	7.40	25.4	YES	469
9	1.15	63	72.5	8.3	7.60	27.1	YES	469
10	1.15	63	72.5	8.3	7.50	26.2	YES	469
11	1.1	63	69.3	8.3	7.50	26.0	YES	469
12	1.16	63	73.1	9.0	7.50	25.0	YES	469
13	1.16	63	73.1	8.9	7.50	25.2	YES	469
14	0.97	63	61.1	9.2	7.50	24.2	YES	469
15	1.18	63	74.3	9.4	7.40	23.6	YES	469
16	0.93	63	58.6	9.2	7.40	23.2	YES	469
17	1.2	63	75.6	9.0	7.50	25.1	YES	469
18	0.95	63	59.9	8.5	7.00	21.2	YES	469
19	0.98	63	61.7	8.8	7.50	24.8	YES	469
20	0.93	63	58.6	8.3	7.50	25.5	YES	469
21	off	off	off	off	off	off	off	off
22	0.76	63	47.9	8.4	7.50	24.9	YES	469
23	0.98	63	61.7	8.4	7.50	25.5	YES	469
24	0.98	63	61.7	9.6	7.40	22.7	YES	469
25	1.05	63	66.2	9.6	7.50	23.7	YES	469
26	1.02	63	64.3	9.6	7.60	24.5	YES	469
27	0.93	63	58.6	10.4	7.50	22.2	YES	469
28	0.95	63	59.9	9.3	7.50	23.9	YES	469

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to: