

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Douglas**
 Month/Year: **Jan-21**

System Name:	City of Yoncalla		ID#: 4100968				WTP: TP -	A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]	
1	off	off	0.04	0.04	0.03	off	0.04	
2	off	off	0.03	0.03	0.03	off	0.03	
3	off	off	0.04	0.03	0.03	off	0.04	
4	off	off	0.03	0.03	0.03	off	0.03	
5	off	off	0.03	0.03	0.03	off	0.03	
6	off	off	0.03	0.03	0.03	off	0.03	
7	off	off	0.04	0.04	0.05	off	0.05	
8	off	off	0.03	0.08	0.08	off	0.08	
9	off	off	0.03	0.04	0.04	off	0.04	
10	off	off	0.04	0.03	0.03	off	0.04	
11	off	off	0.04	0.04	0.03	off	0.04	
12	off	off	0.04	0.03	0.03	off	0.04	
13	off	off	0.04	0.03	0.03	off	0.04	
14	off	off	0.03	0.03	0.03	off	0.03	
15	off	off	0.03	0.03	0.04	off	0.04	
16	off	off	0.04	0.03	0.03	off	0.04	
17	off	off	0.05	0.06	0.04	off	0.06	
18	off	off	0.04	0.03	0.03	off	0.04	
19	off	off	0.04	0.03	0.04	off	0.04	
20	off	off	0.05	0.03	0.04	off	0.05	
21	off	off	0.03	0.04	0.03	off	0.04	
22	off	off	0.04	0.04	0.04	off	0.04	
23	off	off	0.04	0.04	0.04	off	0.04	
24	off	off	0.03	0.05	0.04	off	0.05	
25	off	off	0.03	0.03	0.03	off	0.03	
26	off	off	0.03	0.03	0.03	off	0.03	
27	off	off	0.04	0.04	0.04	off	0.04	
28	off	off	0.03	0.03	0.03	off	0.03	
29	off	off	0.03	0.04	0.03	off	0.04	
30	off	off	0.03	0.03	0.03	off	0.03	
31	off	off	0.03	0.03	0.03	off	0.03	

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings \leq 0.3 NTU? All 4-hour turbidity readings \leq 1 NTU? All turbidity readings < IFE ² triggers	CT's met everyday? (see back) Yes	All Cl2 residual at entry point \geq 0.2 mg/l? Yes

Notes:

Printed Darrel Lockard
 SIGNATURE: *Darrel Lockard*
 Phone# 541-222-9997
 02/08/21
 CERT# 2853

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:		City of Yoncalla		ID#: 4100958	Month/Year:	21-Jan	Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	0.62	62	38.4	8.9	8.04	28.7	YES	350
2	0.52	62	32.2	9.0	8.24	30.3	YES	350
3	0.6	62	37.2	9.0	8.12	29.3	YES	350
4	0.58	62	36.0	9.0	8.16	29.6	YES	350
5	0.94	62	58.3	9.3	7.85	27.1	YES	360
6	0.83	62	51.5	8.3	8.12	31.6	YES	350
7	0.65	62	40.3	8.5	8.00	29.2	YES	350
8	0.59	62	36.6	8.7	8.12	29.9	YES	350
9	0.64	62	39.7	8.4	7.96	28.9	YES	350
10	0.59	62	36.6	8.4	7.94	28.6	YES	350
11	0.5	62	31.0	7.9	8.10	31.0	YES	350
12	0.56	62	34.7	8.3	7.98	29.1	YES	350
13	0.69	62	42.8	8.9	7.90	27.5	YES	350
14	0.59	62	36.6	9.2	7.94	27.1	YES	350
15	0.67	62	41.5	9.6	7.87	25.9	YES	350
16	0.64	62	39.7	9.4	7.87	26.2	YES	350
17	0.58	62	36.0	10.6	7.98	25.0	YES	350
18	0.62	62	38.4	10.0	7.58	22.6	YES	350
19	0.6	62	37.2	9.5	7.97	26.8	YES	350
20	0.63	62	39.1	9.2	7.99	27.7	YES	350
21	0.67	62	41.5	8.8	8.04	29.1	YES	350
22	0.83	62	51.5	9.0	7.96	28.4	YES	350
23	0.72	62	44.6	9.0	7.91	27.5	YES	350
24	0.8	62	49.6	8.9	7.90	27.9	YES	350
25	0.72	62	44.6	8.6	7.99	29.1	YES	350
26	0.77	62	47.7	8.3	7.97	29.7	YES	350
27	0.88	62	54.6	8.0	7.97	30.7	YES	350
28	0.86	62	53.3	7.8	7.90	30.2	YES	350
29	0.67	62	41.5	8.0	7.70	27.2	YES	350
30	0.87	62	53.9	8.3	8.05	30.9	YES	350
31	0.75	62	46.5	8.0	8.08	31.4	YES	350

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.