

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jun-22

System Name:	City of Yoncalla	ID#: 4100958	WTP : TP -				A
Day	24:00 [NTU]	04:00 [NTU]	08:00 [NTU]	12:00 [NTU]	16:00 [NTU]	20:00 [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	0.07	0.05	0.05	off	0.07
2	off	off	0.09	0.05	0.05	off	0.09
3	off	off	0.05	0.10	0.05	off	0.10
4	off	off	0.10	0.07	0.08	off	0.10
5	off	off	0.04	0.08	0.24	off	0.24
6	off	off	0.04	0.03	0.04	off	0.04
7	off	off	0.04	0.04	0.04	off	0.04
8	off	off	0.03	0.03	0.04	off	0.04
9	off	off	0.03	0.04	0.04	off	0.04
10	off	off	0.06	0.09	0.05	off	0.09
11	off	off	0.09	0.05	0.05	off	0.09
12	off	off	0.05	0.10	0.04	off	0.10
13	off	off	0.06	0.04	0.04	off	0.06
14	off	off	0.04	0.04	0.04	off	0.04
15	off	off	0.04	0.05	0.04	off	0.05
16	off	off	NC	0.04	0.04	off	0.04
17	off	off	0.04	0.07	0.04	off	0.07
18	off	off	0.04	0.04	0.04	off	0.04
19	off	off	0.05	0.09	0.04	off	0.09
20	off	off	0.04	0.04	0.05	off	0.05
21	off	off	0.05	0.04	0.09	off	0.09
22	off	off	0.04	0.04	0.04	off	0.04
23	off	off	0.05	0.04	0.04	off	0.05
24	off	off	0.04	0.05	0.04	off	0.05
25	off	off	0.08	off	0.05	off	0.08
26	off	off	0.05	0.05	0.05	off	0.05
27	off	off	0.05	0.05	0.05	off	0.05
28	off	off	0.05	0.05	0.06	off	0.06
29	off	off	0.05	0.07	0.06	off	0.07
30	off	off	0.06	0.07	0.08	off	0.08
31	off	off				off	0.00

Monthly Summary (Answer Yes or No)		
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE ² triggers	<div style="border: 2px solid black; border-radius: 15px; padding: 5px; display: inline-block;">yes</div> Yes Yes	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	City of Yoncalla	ID#: 4100958	Month/Year:	22-May	Disinfection <i>Giardia</i> Log Inactiv:	0.5
--------------	------------------	--------------	-------------	--------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/0800	0.74	66	48.8	18.6	8.60	18.8	YES	190
2/0800	0.74	66	48.8	19.0	8.60	18.3	YES	190
3/0800	0.8	66	52.8	19.3	8.70	18.8	YES	190
4/0800	0.61	66	40.3	19.4	8.70	18.2	YES	190
5/0800	0.65	66	42.9	19.3	8.40	16.5	YES	190
6/0800	0.81	66	53.5	19.5	8.40	16.6	YES	190
7/0800	0.78	66	51.5	19.5	8.50	17.2	YES	190
8/0800	0.78	66	51.5	19.5	8.40	16.5	YES	190
9/0800	0.71	66	46.9	19.7	8.50	16.8	YES	190
10/0800	0.76	66	50.2	19.9	8.70	17.9	YES	190
11/0800	0.77	66	50.8	19.8	8.70	18.1	YES	190
12/0800	0.55	66	36.3	20.1	8.40	15.5	YES	190
13/0800	0.72	66	47.5	19.8	8.20	14.9	YES	190
14/0800	0.62	66	40.9	19.7	8.20	14.9	YES	190
15/0800	0.64	66	42.2	19.8	8.30	15.4	YES	190
16/0800	0.63	66	41.6	19.9	7.90	13.1	YES	190
17/0800	0.67	66	44.2	20.1	7.90	13.0	YES	190
18/0800	0.74	66	48.8	19.7	7.80	13.0	YES	190
19/0800	0.56	66	37.0	19.8	7.90	13.1	YES	190
20/0800	0.62	66	40.9	19.6	7.80	12.9	YES	190
21/0800	0.65	66	42.9	19.8	7.90	13.3	YES	190
22/0800	0.76	66	50.2	20.2	8.00	13.6	YES	190
23/0800	0.65	66	42.9	20.5	8.10	13.6	YES	190
24/0800	0.78	66	51.5	20.9	8.10	13.5	YES	190
25/0800	0.52	66	34.3	21.4	8.10	12.6	YES	190
26/0800	0.8	66	52.8	21.7	8.20	13.3	YES	190
27/0800	0.7	66	46.2	22.1	8.20	12.8	YES	190
28/0800	0.73	66	48.2	22.5	8.30	13.0	YES	190
29/0800	0.67	66	44.2	22.9	8.40	13.0	YES	190
30/0800	0.51	66	33.7	23.2	8.50	13.0	YES	190
31/0800							NO	190

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.