

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

lincoln

Month/Year:

Apr-23

System Name:		City of Yachats					ID#: 41 00966	WTP : TP -		
Day		12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]		
1		off	off	off	off	off	off	off		
2		off	off	off	off	off	off	off		
3		off	off	off	off	off	off	off		
4		off	off	off	off	0.05	0.04	0.05		
5		0.04	0.04	off	off	off	off	0.04		
6		off	off	0.05	0.06	off	off	0.06		
7		off	off	0.05	0.05	off	off	0.05		
8		off	off	off	off	off	off	off		
9		off	off	off	off	off	off	off		
10		off	off	off	off	0.05	0.05	0.05		
11		off	off	off	0.06	off	off	0.06		
12		off	off	off	0.04	off	off	0.04		
13		off	off	0.05	0.05	0.05	0.05	0.05		
14		0.05	0.07	0.07	0.07	off	off	0.07		
15		off	off	off	off	off	off	off		
16		off	off	off	off	off	off	off		
17		off	off	off	0.02	off	off	0.02		
18		off	off	off	0.04	0.05	0.05	0.05		
19		0.05	off	off	off	0.05	0.06	0.06		
20		0.05	off	off	off	0.05	off	0.05		
21		off	off	off	off	0.03	off	0.03		
22		off	off	off	off	off	off	off		
23		off	off	off	off	off	off	off		
24		off	off	off	0.03	0.03	0.03	0.03		
25		0.04	0.05	off	off	off	off	0.05		
26		off	off	0.05	0.06	off	off	0.06		
27		off	off	0.04	0.04	0.04	0.04	0.04		
28		off	off	0.02	off	off	off	0.02		
29		off	off	off	off	off	off	off		
30		off	off	off	off	off	off	off		
31										
Conventional or Direct Filtration							Monthly Summary (Answer Yes or No)			
95% of 4-hour turbidity readings ≤ 0.3 NTU?				Yes	CT's met everyday? (see back)			All Cl ₂ residual at entry point ≥ 0.2 mg/l?		
All 4-hour turbidity readings ≤ 1 NTU?				Yes				Yes		
All turbidity readings < IFE ² triggers				Yes						
Notes:							PRINTED NAME: Rick McClung			
							SIGNATURE:			
							PHONE #: (541) 961-3845			
							DATE: 5.10.23			
							CERT #: 2725			

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Yachats	ID#: 41 00966	Month/Year:	Apr-23	Disinfection Giardia Log Inactiv:	1
--------------	-----------------	---------------	-------------	--------	-----------------------------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	72	57.6	11	7.4	40.6	yes	350
2	0.8	72	57.6	12	7.4	38.1	yes	350
3	0.9	72	64.8	12	7.5	39.9	yes	350
4	1.1	72	79.2	11	7.4	42.0	yes	350
5	1.0	72	72.0	11	7.5	43.0	yes	350
6	0.9	72	64.8	10	7.0	38.2	yes	350
7	0.8	72	57.6	9	7.0	40.3	yes	350
8	0.6	72	43.2	10	7.0	36.9	yes	350
9	0.7	72	50.4	11	7.4	40.2	yes	350
10	0.8	72	57.6	10	7.1	39.1	yes	350
11	0.9	72	64.8	12	7.1	34.7	yes	350
12	0.9	72	64.8	11	7.0	35.8	yes	350
13	0.8	72	57.6	12	7.0	33.2	yes	350
14	0.9	72	64.8	11	7.1	37.0	yes	350
15	0.9	72	64.8	10	7.0	38.2	yes	350
16	0.9	72	64.8	9	7.2	43.7	yes	350
17	0.9	72	64.8	12	7.0	33.6	yes	350
18	0.8	72	57.6	11	7.3	39.2	yes	350
19	0.9	72	64.8	11	7.3	39.7	yes	350
20	0.9	72	64.8	10	7.3	42.4	yes	350
21	1.0	72	72.0	12	7.2	36.3	yes	350
22	0.8	72	57.6	12	7.2	35.5	yes	350
23	0.8	72	57.6	12	7.2	35.5	yes	350
24	0.8	72	57.6	11	7.2	37.9	yes	350
25	0.8	72	57.6	12	7.1	34.3	yes	350
26	0.7	72	50.4	12	7.2	35.1	yes	350
27	0.8	72	57.6	12	7.0	33.2	yes	350
28	0.8	72	57.6	13	7.1	31.6	yes	350
29	0.8	72	57.6	12	7.1	34.3	yes	350
30	0.8	72	57.6	13	7.0	30.4	yes	350
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013