



Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	0.021	0.022	0.026	0.025	OFF	0.026	426
2	OFF	0.021	0.021	0.023	0.025	OFF	0.025	427
3	OFF	0.021	0.021	0.023	0.030	OFF	0.030	423
4	OFF	0.020	0.021	0.024	0.022	OFF	0.024	413
5	OFF	0.022	0.021	0.030	0.022	OFF	0.030	415
6	OFF	0.024	0.021	0.021	0.022	0.022	0.024	415
7	OFF	0.023	0.021	0.021	0.022	OFF	0.023	418
8	OFF	0.026	0.021	0.021	0.022	OFF	0.026	416
9	OFF	0.021	0.027	0.021	0.022	OFF	0.027	409
10	OFF	0.022	0.026	0.021	0.021	OFF	0.026	401
11	0.025	0.021	0.021	0.021	OFF	OFF	0.025	411
12	OFF	0.024	0.021	0.021	0.021	OFF	0.024	421
13	OFF	0.022	0.021	0.022	OFF	0.026	0.026	415
14	OFF	OFF	0.027	0.022	0.022	OFF	0.027	420
15	OFF	0.022	0.022	0.023	OFF	OFF	0.023	416
16	0.021	0.021	OFF	0.026	0.022	0.022	0.026	407
17	OFF	OFF	0.030	OFF	0.022	0.022	0.030	395
18	0.021	OFF	0.027	0.022	0.022	0.022	0.027	401
19	OFF	OFF	0.022	0.023	0.022	0.028	0.028	408
20	OFF	0.020	0.022	0.029	0.022	OFF	0.029	404
21	0.026	0.021	0.031	0.024	OFF	OFF	0.031	410
22	0.023	0.022	OFF	0.024	0.025	OFF	0.025	418
23	OFF	0.021	0.022	0.024	0.023	0.022	0.024	399
24	OFF	0.023	0.021	0.021	0.024	OFF	0.024	426
25	OFF	0.021	0.020	0.027	OFF	OFF	0.027	425
26	0.021	0.020	0.020	OFF	OFF	0.029	0.029	414
27	0.020	OFF	0.027	0.021	0.021	OFF	0.027	407
28	OFF	0.020	0.020	OFF	0.031	OFF	0.031	428
29	OFF	0.020	0.020	0.020	0.026	OFF	0.026	418
30	OFF	0.020	0.021	OFF	0.035	OFF	0.035	402
31	OFF	0.020	0.021	0.021	0.023	OFF	0.023	425

You are using a Slow Sand or Cartridge Filter <input type="checkbox"/> Monthly Summary	
95% of Turbidity readings < MCL Y / N All Turbidity readings < 5 NTU Y / N	CT's met every day: Yes / No (see back of sheet)
Cl residual at entry point always $\geq$ .2 mg/l Yes / No	Cl Residual measured in 95% of distribution samples Yes / No

MCL is 0.5 for conventional and direct filtration  
and 1.0 for slow sand and diatomaceous earth filters

Signature: \_\_\_\_\_

Date: 8/8/2024 \_\_\_\_\_

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: WTP-A

System Name: Yamhill, City of ID#: OR4100968 Month/Year: Jul-24 Disinfection Giardia Log Inactiv: 0.500

Date / Time	Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/13:00	0.7	80.00	54.2	13.3	8.3	23.6	YES	425
2/9:00	0.7	80.00	56.5	13.2	8.2	23.2	YES	424
3/16:00	0.7	80.00	56.5	12.7	8.2	24.1	YES	416
4/11:00	0.7	80.00	57.7	12.8	8.2	24.0	YES	405
5/12:00	0.7	80.00	57.2	14.1	8.2	21.9	YES	432
6/19:00	0.7	80.00	53.0	16.3	8.3	19.3	YES	415
7/11:00	0.7	80.00	52.6	15.7	8.3	20.0	YES	411
8/17:00	0.6	80.00	51.8	16.6	8.3	18.9	YES	409
9/16:00	0.6	80.00	51.8	17.0	8.3	18.4	YES	418
10/11:00	0.7	80.00	54.7	16.8	8.3	18.8	YES	421
11/19:00	0.6	80.00	51.9	15.4	8.2	19.9	YES	413
12/9:00	0.6	80.00	49.1	15.6	8.2	19.8	YES	408
13/22:00	0.7	80.00	53.4	16.5	8.2	18.8	YES	415
14/19:00	0.7	80.00	52.9	17.1	8.2	18.0	YES	416
15/7:00	0.6	80.00	49.5	16.6	8.2	18.5	YES	404
16/22:00	0.6	80.00	49.1	17.1	8.2	17.9	YES	407
17/20:00	0.6	80.00	50.8	16.9	8.3	18.5	YES	397
18/10:00	0.7	80.00	56.0	16.3	8.3	19.1	YES	411
19/17:00	0.6	80.00	50.9	15.6	8.3	19.9	YES	403
20/9:00	0.6	80.00	49.6	16.1	8.2	19.0	YES	407
21/1:00	0.7	80.00	52.9	16.4	8.3	19.0	YES	411
22/13:00	0.7	80.00	57.1	15.6	8.2	19.9	YES	417
23/10:00	0.8	80.00	61.1	13.9	8.3	23.5	YES	395
24/13:00	0.7	80.00	57.1	13.9	8.3	23.2	YES	423
25/13:00	0.7	80.00	57.0	12.9	8.3	24.8	YES	420
26/7:00	0.7	80.00	55.7	12.9	8.3	24.8	YES	409
27/17:00	0.7	80.00	53.0	14.2	8.4	22.9	YES	405
28/16:00	0.7	80.00	53.1	13.8	8.4	23.4	YES	420
29/16:00	0.7	80.00	57.2	13.4	8.3	24.0	YES	402
30/11:00	0.7	80.00	53.4	13.6	8.3	23.5	YES	400
31/16:00	0.7	80.00	54.2	14.1	8.3	22.8	YES	401

<sup>3</sup> If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013