

Oregon Health Authority Drinking Water Section

System Name: Yreka, City of
Turbidity Monitoring Report Form
ID# OH4100968

June 2025

Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	OFF	0.022	0.020	0.019	0.020	0.022	401
2	OFF	OFF	0.021	OFF	0.020	0.019	0.021	404
3	0.019	OFF	OFF	0.010	0.020	OFF	0.020	410
4	OFF	OFF	OFF	0.025	0.025	0.024	0.025	396
5	OFF	OFF	OFF	0.022	0.027	0.023	0.027	404
6	OFF	OFF	OFF	0.019	0.018	0.019	0.019	405
7	0.021	OFF	OFF	0.020	0.021	0.020	0.023	398
8	OFF	OFF	OFF	0.022	0.025	0.023	0.021	392
9	0.023	OFF	OFF	0.028	0.024	0.024	0.025	396
10	0.026	OFF	OFF	0.019	0.021	0.021	0.023	404
11	0.025	OFF	0.030	0.033	0.028	0.025	0.023	392
12	0.025	OFF	OFF	OFF	0.022	0.025	0.023	388
13	0.020	OFF	OFF	OFF	0.019	0.020	0.025	391
14	OFF	OFF	OFF	0.024	0.021	0.021	0.021	401
15	OFF	OFF	OFF	0.019	0.019	0.021	0.024	399
16	OFF	OFF	OFF	0.033	0.023	0.022	0.023	404
17	OFF	OFF	OFF	0.026	0.023	0.020	0.026	393
18	OFF	OFF	OFF	0.021	0.023	0.024	0.025	406
19	OFF	OFF	OFF	0.022	0.020	0.022	0.022	397
20	OFF	OFF	OFF	0.021	0.027	OFF	0.027	392
21	OFF	0.020	OFF	0.023	0.019	OFF	0.023	400
22	OFF	OFF	OFF	0.020	0.021	OFF	0.021	404
23	OFF	OFF	OFF	0.024	0.024	0.022	0.024	407
24	OFF	OFF	0.026	0.031	0.028	0.034	0.031	395
25	OFF	OFF	0.028	0.030	0.034	0.029	0.034	390
26	OFF	OFF	0.023	0.020	0.022	OFF	0.023	394
27	0.022	OFF	0.023	OFF	0.024	0.024	0.025	395
28	0.013	0.020	0.019	OFF	0.020	0.020	0.022	402
29				0.019	0.019	0.024	0.024	392
30								

You are using a 510W Sand or Cartridge Filter ☐ Monthly Summary

95% of turbidity readings < 0.5 NTU ☒ NTU test every day (NTU) less than 0.5 NTU ☐ NTU test at water entry always < 2 NTU / day ☐ NTU test at water entry 95% of readings < 0.5 NTU ☐

ALCL is 0.5 for conventional and direct filtration
and 1.0 for slow sand and disinfection with filters

Signature: *[Signature]*

Date: 7/10/2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: WTP-A

System Name: Yamhill, City of ID#: OHA-000000 Month/Year: Jun-05

Sanitation Standard Log (Required)

0.006

Date / Time	Residual Chlorine 1st Line (mg/L)	Conductivity (µmhos/cm)	Actual CT (min)	Temp (°C)	pH	Required CT (min)	CT Met?	Peak Hourly Disinfectant Flow
1/13:00	0.6	80.00	49.7	12.8	8.0	10.0	Yes / No	390mg
2/15:00	0.6	80.00	44.3	13.0	8.0	21.2	YES	401
3/23:00	0.6	80.00	60.5	12.7	8.0	22.7	YES	404
4/23:00	0.6	80.00	71.8	12.5	8.0	23.2	YES	410
5/23:00	0.6	80.00	60.0	13.1	8.0	21.8	YES	398
6/23:00	0.6	80.00	63.1	14.4	8.0	20.2	YES	404
7/23:00	0.7	80.00	53.8	15.0	8.0	19.0	YES	405
8/12:00	0.6	80.00	47.4	14.9	8.0	19.1	YES	398
9/14:00	0.6	80.00	61.3	15.8	8.0	18.2	YES	392
10/18:00	0.6	80.00	61.1	15.6	8.0	18.2	YES	390
11/16:00	0.7	80.00	68.4	14.8	8.0	18.4	YES	404
12/19:00	0.7	80.00	58.5	13.5	8.0	21.2	YES	392
13/14:00	0.7	80.00	58.2	13.3	8.0	21.5	YES	388
14/20:00	0.7	80.00	54.7	12.0	8.0	23.2	YES	391
15/14:00	0.7	80.00	57.5	12.1	8.0	23.3	YES	401
16/14:00	0.7	80.00	57.4	12.7	8.0	22.2	YES	399
17/18:00	0.7	80.00	53.0	13.1	8.0	21.8	YES	404
18/12:00	0.7	80.00	65.2	13.3	8.0	21.4	YES	393
19/13:00	0.6	80.00	51.2	13.3	8.0	21.2	YES	401
20/21:00	0.7	80.00	54.8	12.8	8.0	22.1	YES	406
21/17:00	0.7	80.00	52.4	11.7	8.0	23.7	YES	397
22/18:00	0.6	80.00	48.0	12.0	8.0	23.1	YES	392
23/13:00	0.7	80.00	57.5	12.8	8.0	22.5	YES	400
24/18:00	0.7	80.00	55.5	13.6	8.0	20.8	YES	404
25/12:00	0.7	80.00	68.7	14.0	8.0	20.5	YES	407
26/18:00	0.9	80.00	70.2	13.3	8.0	21.4	YES	395
27/15:00	0.9	80.00	67.8	13.2	8.0	21.9	YES	380
28/20:00	0.8	80.00	66.7	13.9	8.0	20.8	YES	394
29/12:00	0.8	80.00	63.7	14.0	8.0	20.8	YES	393
30/4:00	0.8	80.00	60.0	15.1	8.0	19.2	YES	402

1. If CT at entry point < 0.2 mg/L or CT not met, OHA to be notified by end of next business day.

Revised October 2014

PAGE 3 of 3