

Oregon Health Authority Drinking Water Section

Turbidity Monitoring Report Form

System Name: Yamhill, City of

ID#: OR4100968

July 2025

Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	OFF	OFF	OFF	0.023	0.021	0.023	402
2	0.023	0.022	0.022	OFF	OFF	0.021	0.023	392
3	0.026	0.023	0.034	OFF	0.026	OFF	0.034	397
4	OFF	OFF	OFF	0.025	0.022	0.021	0.025	404
5	OFF	OFF	OFF	0.020	0.020	0.019	0.020	400
6	0.019	OFF	OFF	0.020	0.022	OFF	0.022	406
7	OFF	OFF	OFF	0.020	0.020	0.022	0.022	412
8	0.020	0.019	0.021	OFF	0.021	0.020	0.021	406
9	0.019	0.020	0.019	OFF	OFF	0.022	0.022	400
10	0.024	0.026	0.031	0.030	0.028	0.021	0.031	396
11	OFF	OFF	0.023	0.025	0.021	0.024	0.025	399
12	OFF	OFF	0.019	0.021	0.021	OFF	0.021	395
13	OFF	OFF	OFF	0.022	0.021	0.021	0.022	403
14	OFF	OFF	OFF	0.023	0.022	0.020	0.023	401
15	OFF	OFF	OFF	0.019	0.023	0.021	0.023	406
16	OFF	OFF	0.019	0.020	0.020	0.021	0.021	408
17	0.024	0.032	0.030	OFF	0.026	0.022	0.032	396
18	OFF	OFF	OFF	0.021	0.020	0.020	0.021	393
19	OFF	OFF	0.018	0.019	0.019	OFF	0.019	400
20	OFF	OFF	OFF	0.024	0.020	0.020	0.024	395
21	OFF	OFF	0.020	OFF	0.023	0.021	0.023	398
22	OFF	OFF	0.022	0.019	0.019	0.020	0.022	402
23	OFF	OFF	OFF	0.020	0.020	OFF	0.020	408
24	0.020	OFF	OFF	0.019	0.022	0.021	0.022	405
25	OFF	OFF	OFF	0.020	0.020	0.019	0.020	399
26	OFF	OFF	0.020	0.021	0.020	0.019	0.020	408
27	OFF	0.020	0.024	OFF	0.022	OFF	0.024	402
28	OFF	OFF	0.021	0.021	0.020	0.021	0.021	409
29	OFF	OFF	OFF	0.019	0.023	0.020	0.023	400
30	OFF	OFF	OFF	0.022	0.020	0.020	0.022	394
31	OFF	OFF	OFF	0.021	0.021	0.020	0.021	399

You are using a Slow Sand or Cartridge Filter

Monthly Summary

95% of Turbidity readings < MCL Y/N

All Turbidity readings < 5 NTU Y/N

 CT's met every day: Yes / No
(see back of sheet)

 Cl residual at entry point
always ≥ .2 mg/l Yes / No

 Cl Residual measured in
95% of distribution
samples Yes / No

MCL is 0.5 for conventional and direct filtration
and 1.0 for slow sand and diatomaceous earth filters

Signature:



Date: 8/10/2025

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: WTP-A

System Name: Yamhill, City of		ID#: OR4100968	Month/Year: Jul-25		Disinfection Giardia Log Inactiv:		0.500	
Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/22:00	0.7	80.00	58.5	16.7	7.98	17.0	YES	402
2/4:00	0.8	80.00	61.6	16.0	7.99	18.0	YES	392
3/18:00	0.7	80.00	57.8	14.0	8.02	20.6	YES	397
4/14:00	0.9	80.00	75.6	14.3	8.01	20.6	YES	404
5/15:00	0.9	80.00	69.2	14.1	8.00	20.6	YES	400
6/17:00	0.7	80.00	59.4	14.5	8.03	20.0	YES	406
7/21:00	0.8	80.00	66.1	15.8	8.01	18.4	YES	412
8/1:00	0.9	80.00	69.1	15.9	7.99	18.2	YES	406
9/8:00	0.8	80.00	66.5	15.2	7.97	18.9	YES	400
10/18:00	0.8	80.00	62.1	14.6	8.00	19.7	YES	396
11/13:00	0.8	80.00	68.0	15.3	8.01	19.1	YES	399
12/14:00	0.8	80.00	65.7	16.4	7.99	17.5	YES	395
13/14:00	0.7	80.00	56.1	17.1	8.02	16.7	YES	403
14/11:00	0.9	80.00	72.4	18.0	8.03	16.2	YES	401
15/11:00	0.7	80.00	58.8	17.1	8.00	16.6	YES	406
16/15:00	0.7	80.00	59.8	17.0	8.01	16.8	YES	408
17/22:00	0.9	80.00	70.4	16.4	8.00	17.7	YES	396
18/17:00	0.9	80.00	69.4	16.6	7.98	17.3	YES	393
19/15:00	0.8	80.00	63.2	15.6	8.00	18.5	YES	400
20/18:00	0.8	80.00	64.5	14.7	8.03	19.9	YES	395
21/19:00	0.8	80.00	65.5	14.9	8.05	19.8	YES	398
22/20:00	0.8	80.00	62.5	15.2	8.00	19.0	YES	402
23/11:00	1.0	80.00	77.0	15.5	8.02	19.2	YES	408
24/11:00	0.7	80.00	58.9	16.0	8.00	17.9	YES	405
25/18:00	1.0	80.00	76.3	15.8	7.98	18.5	YES	399
26/15:00	0.8	80.00	62.7	15.3	7.99	18.8	YES	408
27/7:00	0.9	80.00	68.6	14.0	8.02	20.9	YES	402
28/20:00	0.9	80.00	74.9	15.0	8.00	19.6	YES	409
29/13:00	1.0	80.00	79.5	15.2	8.00	19.4	YES	400
30/20:00	0.9	80.00	73.4	15.9	7.99	18.3	YES	394
31/11:00	0.9	80.00	72.1	15.8	8.02	18.6	YES	399

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013